

Max Farm Production (MW)	Crystal Rig II							Site Capped	Additional Information	Created On	
	Expected Max Output (MW)										Estimated End
	Start	Time 1	Time 2	Time 3	Time 4	Time 5	Time 6				
138	128.8(MW)	128.8(MW)	128.8(MW)	138(MW)	138(MW)	138(MW)	138(MW)	17/05/2019 00:36	N	Service	16/05/2019 12:36
	16/05/2019 12:36	16/05/2019 16:36	16/05/2019 20:36	17/05/2019 00:36	17/05/2019 04:36	17/05/2019 08:36	17/05/2019 12:36				
138	121.9(MW)	121.9(MW)	121.9(MW)	138(MW)	138(MW)	138(MW)	138(MW)	16/05/2019 16:00	N	7 turbines offline.	16/05/2019 04:22
	16/05/2019 04:00	16/05/2019 08:00	16/05/2019 12:00	16/05/2019 16:00	16/05/2019 20:00	17/05/2019 00:00	17/05/2019 04:00				
138	112.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	01/05/2019 16:50	N	HV works ongoing.	01/05/2019 12:50
	01/05/2019 12:50	01/05/2019 16:50	01/05/2019 20:50	02/05/2019 00:50	02/05/2019 04:50	02/05/2019 08:50	02/05/2019 12:50				
138	128.8(MW)	128.8(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	19/04/2019 16:19	N	Servicing and isolations	19/04/2019 12:20
	19/04/2019 12:19	19/04/2019 16:19	19/04/2019 20:19	20/04/2019 00:19	20/04/2019 04:19	20/04/2019 08:19	20/04/2019 12:19				
138	103.5(MW)	103.5(MW)	103.5(MW)	103.5(MW)	138(MW)	138(MW)	138(MW)	19/04/2019 00:31	N	Array 5 turbines in warmup mode	18/04/2019 08:34
	18/04/2019 08:31	18/04/2019 12:31	18/04/2019 16:31	18/04/2019 20:31	19/04/2019 00:31	19/04/2019 04:31	19/04/2019 08:31				
138	103.5(MW)	103.5(MW)	108.1(MW)	108.1(MW)	108.1(MW)	108.1(MW)	108.1(MW)	17/04/2019 16:50	N	13 Turbines in warm-up, 2x maintenance	17/04/2019 12:54
	17/04/2019 12:50	17/04/2019 16:50	17/04/2019 20:50	18/04/2019 00:50	18/04/2019 04:50	18/04/2019 08:50	18/04/2019 12:50				
138	87.4(MW)	87.4(MW)	105.8(MW)	105.8(MW)	105.8(MW)	105.8(MW)	105.8(MW)	16/04/2019 16:18	N	Array 5. Circuit 3 HV testing and switching.	16/04/2019 12:19
	16/04/2019 12:18	16/04/2019 16:18	16/04/2019 20:18	17/04/2019 00:18	17/04/2019 04:18	17/04/2019 08:18	17/04/2019 12:18				
138	105.8(MW)	105.8(MW)	105.8(MW)	105.8(MW)	105.8(MW)	105.8(MW)	105.8(MW)	16/04/2019 00:00	N	14 turbines offline	15/04/2019 20:47
	15/04/2019 20:00	16/04/2019 00:00	16/04/2019 04:00	16/04/2019 08:00	16/04/2019 12:00	16/04/2019 16:00	16/04/2019 20:00				
	105.8(MW)	108.1(MW)	108.1(MW)	108.1(MW)	108.1(MW)	108.1(MW)	108.1(MW)			Turbines offline for ongoing Repairs and Maintenance Works	

Max Farm Production (MW)	Crystal Rig II								Site Capped	Additional Information	Created On
	Expected Max Output (MW)							Estimated End			
	Start	Time 1	Time 2	Time 3	Time 4	Time 5	Time 6				
138	15/04/2019 12:00	15/04/2019 16:00	15/04/2019 20:00	16/04/2019 00:00	16/04/2019 04:00	16/04/2019 08:00	16/04/2019 12:00	15/04/2019 16:00	N		15/04/2019 12:45
138	108.1(MW)	-	-	-	-	-	-	15/04/2019 09:00	N	HV Fault	13/04/2019 08:21
	13/04/2019 08:17	-	-	-	-	-	-				
138	101.2(MW)	101.2(MW)	108.1(MW)	108.1(MW)	108.1(MW)	108.1(MW)	108.1(MW)	12/04/2019 12:37	N	13 x Switchgear investigation, 3 x maintenance	12/04/2019 08:41
	12/04/2019 08:37	12/04/2019 12:37	12/04/2019 16:37	12/04/2019 20:37	13/04/2019 00:37	13/04/2019 04:37	13/04/2019 08:37				
138	108.1(MW)	-	-	-	-	-	-	12/04/2019 17:30	N	2 Cross boundary isolations, 11 switchgear replacement after HV trip.	08/04/2019 17:08
	08/04/2019 17:06	-	-	-	-	-	-				
138	108.1(MW)	-	-	-	-	-	-	08/04/2019 17:30	N	array 5 HV fault	06/04/2019 14:10
	06/04/2019 14:30	-	-	-	-	-	-				
138	108.1(MW)	-	-	-	-	-	-	08/04/2019 17:30	N	Array 5 HV fault	06/04/2019 13:50
	06/04/2019 12:45	-	-	-	-	-	-				
138	101.2(MW)	101.2(MW)	108.1(MW)	108.1(MW)	108.1(MW)	108.1(MW)	108.1(MW)	05/04/2019 16:37	N	HV switchgear, faults and service	05/04/2019 12:45
	05/04/2019 12:37	05/04/2019 16:37	05/04/2019 20:37	06/04/2019 00:37	06/04/2019 04:37	06/04/2019 08:37	06/04/2019 12:37				
138	105.8(MW)	-	-	-	-	-	-	08/04/2019 16:00	N	Array 5 fault plus faulted turbines	05/04/2019 08:54
	05/04/2019 00:00	-	-	-	-	-	-				
	108.1(MW)	108.1(MW)	108.1(MW)	108.1(MW)	108.1(MW)	108.1(MW)	108.1(MW)			HV Switchgear repair	

Max Farm Production (MW)	Crystal Rig II								Site Capped	Additional Information	Created On
	Expected Max Output (MW)							Estimated End			
	Start	Time 1	Time 2	Time 3	Time 4	Time 5	Time 6				
138	04/04/2019 12:41	04/04/2019 16:41	04/04/2019 20:41	05/04/2019 00:41	05/04/2019 04:41	05/04/2019 08:41	05/04/2019 12:41	04/04/2019 16:41	N		04/04/2019 12:44
138	108.1(MW)	-	-	-	-	-	-	10/04/2019 17:00	N	HV Switchgear works	03/04/2019 12:33
	03/04/2019 12:31	-	-	-	-	-	-				
138	98.9(MW)	105.8(MW)	105.8(MW)	105.8(MW)	105.8(MW)	105.8(MW)	105.8(MW)	03/04/2019 08:25	N		03/04/2019 04:26
	03/04/2019 04:25	03/04/2019 08:25	03/04/2019 12:25	03/04/2019 16:25	03/04/2019 20:25	04/04/2019 00:25	04/04/2019 04:25				
138	105.8(MW)	108.1(MW)	108.1(MW)	108.1(MW)	108.1(MW)	108.1(MW)	108.1(MW)	02/04/2019 16:39	N	HV fault	02/04/2019 12:40
	02/04/2019 12:39	02/04/2019 16:39	02/04/2019 20:39	03/04/2019 00:39	03/04/2019 04:39	03/04/2019 08:39	03/04/2019 12:39				
138	103.5(MW)	103.5(MW)	103.5(MW)	105.8(MW)	105.8(MW)	105.8(MW)	105.8(MW)	01/04/2019 16:16	N	HV investigations	01/04/2019 12:17
	01/04/2019 12:16	01/04/2019 16:16	01/04/2019 20:16	02/04/2019 00:16	02/04/2019 04:16	02/04/2019 08:16	02/04/2019 12:16				
138	101.2(MW)	101.2(MW)	101.2(MW)	101.2(MW)	101.2(MW)	101.2(MW)	101.2(MW)	31/03/2019 20:00	N	HV Investigation and faulted turbines. NP Service aware.	31/03/2019 16:22
	31/03/2019 16:00	31/03/2019 20:00	01/04/2019 00:00	01/04/2019 04:00	01/04/2019 08:00	01/04/2019 12:00	01/04/2019 16:00				
138	103.5(MW)	103.5(MW)	103.5(MW)	103.5(MW)	103.5(MW)	103.5(MW)	103.5(MW)	31/03/2019 16:00	N	HV investigation & faulted turbines.	31/03/2019 12:16
	31/03/2019 12:00	31/03/2019 16:00	31/03/2019 20:00	01/04/2019 00:00	01/04/2019 04:00	01/04/2019 08:00	01/04/2019 12:00				
138	105.8(MW)	105.8(MW)	105.8(MW)	105.8(MW)	105.8(MW)	105.8(MW)	105.8(MW)	30/03/2019 20:00	N	HV investigation & turbine faults	30/03/2019 16:11
	30/03/2019 16:00	30/03/2019 20:00	31/03/2019 00:00	31/03/2019 04:00	31/03/2019 08:00	31/03/2019 12:00	31/03/2019 16:00				
	101.2(MW)	101.2(MW)	101.2(MW)	101.2(MW)	101.2(MW)	101.2(MW)	101.2(MW)			HV investigations & turbine faults	

Max Farm Production (MW)	Crystal Rig II								Site Capped	Additional Information	Created On
	Expected Max Output (MW)							Estimated End			
	Start	Time 1	Time 2	Time 3	Time 4	Time 5	Time 6				
138	30/03/2019 12:00	30/03/2019 16:00	30/03/2019 20:00	31/03/2019 00:00	31/03/2019 04:00	31/03/2019 08:00	31/03/2019 12:00	30/03/2019 16:00	N		30/03/2019 12:24
138	105.8(MW)	105.8(MW)	105.8(MW)	105.8(MW)	105.8(MW)	105.8(MW)	105.8(MW)	29/03/2019 20:00	N	HV Investigations	29/03/2019 16:18
	29/03/2019 16:00	29/03/2019 20:00	30/03/2019 00:00	30/03/2019 04:00	30/03/2019 08:00	30/03/2019 12:00	30/03/2019 16:00				
138	101.2(MW)	105.8(MW)	105.8(MW)	105.8(MW)	105.8(MW)	105.8(MW)	105.8(MW)	29/03/2019 16:00	N	HV fault investigation & turbine maintenance	29/03/2019 12:24
	29/03/2019 12:00	29/03/2019 16:00	29/03/2019 20:00	30/03/2019 00:00	30/03/2019 04:00	30/03/2019 08:00	30/03/2019 12:00				
138	105.8(MW)	105.8(MW)	105.8(MW)	105.8(MW)	105.8(MW)	105.8(MW)	105.8(MW)	29/03/2019 12:56	N	HV fault investigation	29/03/2019 08:57
	29/03/2019 08:56	29/03/2019 12:56	29/03/2019 16:56	29/03/2019 20:56	30/03/2019 00:56	30/03/2019 04:56	30/03/2019 08:56				
138	101.2(MW)	101.2(MW)	101.2(MW)	110.4(MW)	110.4(MW)	110.4(MW)	110.4(MW)	28/03/2019 12:12	N	HV switchgear investigation.	28/03/2019 08:16
	28/03/2019 08:12	28/03/2019 12:12	28/03/2019 16:12	28/03/2019 20:12	29/03/2019 00:12	29/03/2019 04:12	29/03/2019 08:12				
138	103.5(MW)	105.8(MW)	105.8(MW)	105.8(MW)	105.8(MW)	105.8(MW)	105.8(MW)	27/03/2019 12:30	N	HV fault.	27/03/2019 08:43
	27/03/2019 08:30	27/03/2019 12:30	27/03/2019 16:30	27/03/2019 20:30	28/03/2019 00:30	28/03/2019 04:30	28/03/2019 08:30				
138	96.6(MW)	96.6(MW)	96.6(MW)	96.6(MW)	96.6(MW)	96.6(MW)	96.6(MW)	26/03/2019 12:35	N	HV fault.	26/03/2019 08:38
	26/03/2019 08:35	26/03/2019 12:35	26/03/2019 16:35	26/03/2019 20:35	27/03/2019 00:35	27/03/2019 04:35	27/03/2019 08:35				
138	92(MW)	92(MW)	92(MW)	92(MW)	92(MW)	92(MW)	92(MW)	25/03/2019 20:27	N		25/03/2019 16:28
	25/03/2019 16:27	25/03/2019 20:27	26/03/2019 00:27	26/03/2019 04:27	26/03/2019 08:27	26/03/2019 12:27	26/03/2019 16:27				
	59.8(MW)	59.8(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)			HV investigations	

Max Farm Production (MW)	Crystal Rig II								Site Capped	Additional Information	Created On
	Expected Max Output (MW)							Estimated End			
	Start	Time 1	Time 2	Time 3	Time 4	Time 5	Time 6				
138	25/03/2019 12:00	25/03/2019 16:00	25/03/2019 20:00	26/03/2019 00:00	26/03/2019 04:00	26/03/2019 08:00	26/03/2019 12:00	25/03/2019 16:00	N		25/03/2019 12:03
138	57.5(MW)	57.5(MW)	57.5(MW)	57.5(MW)	138(MW)	138(MW)	138(MW)	25/03/2019 20:15	N	2 x faulted - oil pressure 1 x faulted - pitch pump 1 x gearbox replacement 31 x HV trip	25/03/2019 04:16
	25/03/2019 04:15	25/03/2019 08:15	25/03/2019 12:15	25/03/2019 16:15	25/03/2019 20:15	26/03/2019 00:15	26/03/2019 04:15				
138	133.4(MW)	133.4(MW)	133.4(MW)	133.4(MW)	138(MW)	138(MW)	138(MW)	25/03/2019 19:55	N	Restored following trip, 2 x turbines still offline.	25/03/2019 03:57
	25/03/2019 03:55	25/03/2019 07:55	25/03/2019 11:55	25/03/2019 15:55	25/03/2019 19:55	25/03/2019 23:55	26/03/2019 03:55				
138	69(MW)	69(MW)	69(MW)	69(MW)	138(MW)	138(MW)	138(MW)	25/03/2019 15:15	N	HV trip on HPPP01	25/03/2019 00:12
	24/03/2019 23:15	25/03/2019 03:15	25/03/2019 07:15	25/03/2019 11:15	25/03/2019 15:15	25/03/2019 19:15	25/03/2019 23:15				
138	128.8(MW)	128.8(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	22/03/2019 17:16	N	Annual service and gearbox replacement	22/03/2019 13:16
	22/03/2019 13:16	22/03/2019 17:16	22/03/2019 21:16	23/03/2019 01:16	23/03/2019 05:16	23/03/2019 09:16	23/03/2019 13:16				
138	126.5(MW)	126.5(MW)	131.1(MW)	131.1(MW)	131.1(MW)	131.1(MW)	131.1(MW)	13/03/2019 13:14	N		13/03/2019 09:14
	13/03/2019 09:14	13/03/2019 13:14	13/03/2019 17:14	13/03/2019 21:14	14/03/2019 01:14	14/03/2019 05:14	14/03/2019 09:14				
138	128.8(MW)	128.8(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	12/03/2019 16:34	N	Servicing and Gearbox replacement	12/03/2019 12:38
	12/03/2019 12:34	12/03/2019 16:34	12/03/2019 20:34	13/03/2019 00:34	13/03/2019 04:34	13/03/2019 08:34	13/03/2019 12:34				
138	128.8(MW)	128.8(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	04/03/2019 12:24	N	T15 and T55 techs in possession, T2 fault code 3173, T6 awaiting gearbox replacement	04/03/2019 08:29
	04/03/2019 08:24	04/03/2019 12:24	04/03/2019 16:24	04/03/2019 20:24	05/03/2019 00:24	05/03/2019 04:24	05/03/2019 08:24				
	128.8(MW)	133.4(MW)	133.4(MW)	133.4(MW)	133.4(MW)	133.4(MW)	133.4(MW)				

Max Farm Production (MW)	Crystal Rig II								Site Capped	Additional Information	Created On
	Expected Max Output (MW)							Estimated End			
	Start	Time 1	Time 2	Time 3	Time 4	Time 5	Time 6				
138	17/02/2019 16:31	17/02/2019 20:31	18/02/2019 00:31	18/02/2019 04:31	18/02/2019 08:31	18/02/2019 12:31	18/02/2019 16:31	17/02/2019 20:31	N		17/02/2019 16:32
138	128.8(MW)	133.4(MW)	133.4(MW)	133.4(MW)	133.4(MW)	133.4(MW)	133.4(MW)	17/02/2019 16:12	N		17/02/2019 12:12
	17/02/2019 12:12	17/02/2019 16:12	17/02/2019 20:12	18/02/2019 00:12	18/02/2019 04:12	18/02/2019 08:12	18/02/2019 12:12				
138	128.8(MW)	128.8(MW)	133.4(MW)	133.4(MW)	133.4(MW)	133.4(MW)	133.4(MW)	17/02/2019 12:13	N	Faults	17/02/2019 08:15
	17/02/2019 08:13	17/02/2019 12:13	17/02/2019 16:13	17/02/2019 20:13	18/02/2019 00:13	18/02/2019 04:13	18/02/2019 08:13				
138	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	17/02/2019 00:00	N	now only 4 turbines offline with faults.	16/02/2019 20:08
	16/02/2019 20:00	17/02/2019 00:00	17/02/2019 04:00	17/02/2019 08:00	17/02/2019 12:00	17/02/2019 16:00	17/02/2019 20:00				
138	119.6(MW)	121.9(MW)	121.9(MW)	121.9(MW)	121.9(MW)	121.9(MW)	121.9(MW)	16/02/2019 12:16	N	WTG works	16/02/2019 08:17
	16/02/2019 08:16	16/02/2019 12:16	16/02/2019 16:16	16/02/2019 20:16	17/02/2019 00:16	17/02/2019 04:16	17/02/2019 08:16				
138	119.6(MW)	-	-	-	-	-	-	18/02/2019 16:00	N	HV works ongoing.	15/02/2019 13:43
	15/02/2019 13:42	-	-	-	-	-	-				
138	112.7(MW)	-	-	-	-	-	-	18/02/2019 12:00	N	HV works ongoing	14/02/2019 17:08
	14/02/2019 17:06	-	-	-	-	-	-				
138	117.3(MW)	119.6(MW)	119.6(MW)	119.6(MW)	119.6(MW)	119.6(MW)	119.6(MW)	14/02/2019 12:11	N	Faults	14/02/2019 08:12
	14/02/2019 08:11	14/02/2019 12:11	14/02/2019 16:11	14/02/2019 20:11	15/02/2019 00:11	15/02/2019 04:11	15/02/2019 08:11				
	121.9(MW)	-	-	-	-	-	-			7 Turbines offline due to Maintenance and Repairs	

Max Farm Production (MW)	Crystal Rig II							Estimated End	Site Capped	Additional Information	Created On
	Expected Max Output (MW)										
	Start	Time 1	Time 2	Time 3	Time 4	Time 5	Time 6				
138	12/02/2019 04:00	-	-	-	-	-	-	14/02/2019 12:00	N		12/02/2019 04:29
138	121.9(MW)	121.9(MW)	121.9(MW)	121.9(MW)	121.9(MW)	121.9(MW)	121.9(MW)	08/02/2019 16:24	N	Switchgear issues and ongoing gearbox work	08/02/2019 12:25
	08/02/2019 12:24	08/02/2019 16:24	08/02/2019 20:24	09/02/2019 00:24	09/02/2019 04:24	09/02/2019 08:24	09/02/2019 12:24				
138	119.6(MW)	119.6(MW)	121.9(MW)	121.9(MW)	121.9(MW)	121.9(MW)	121.9(MW)	01/02/2019 08:03	N	Faults	08/02/2019 04:04
	01/02/2019 04:03	01/02/2019 08:03	01/02/2019 12:03	01/02/2019 16:03	01/02/2019 20:03	02/02/2019 00:03	02/02/2019 04:03				
138	119.6(MW)	121.9(MW)	121.9(MW)	121.9(MW)	121.9(MW)	121.9(MW)	121.9(MW)	08/02/2019 04:12	N	Faults	08/02/2019 00:13
	08/02/2019 00:12	08/02/2019 04:12	08/02/2019 08:12	08/02/2019 12:12	08/02/2019 16:12	08/02/2019 20:12	09/02/2019 00:12				
138	119.6(MW)	119.6(MW)	119.6(MW)	121.9(MW)	121.9(MW)	121.9(MW)	121.9(MW)	07/02/2019 12:27	N	Gearbox, Annual service and switchgear issues	07/02/2019 08:27
	07/02/2019 08:27	07/02/2019 12:27	07/02/2019 16:27	07/02/2019 20:27	08/02/2019 00:27	08/02/2019 04:27	08/02/2019 08:27				
138	119.6(MW)	119.6(MW)	119.6(MW)	121.9(MW)	121.9(MW)	121.9(MW)	121.9(MW)	06/02/2019 13:41	N	Gearbox and switchgear issues and service	06/02/2019 09:49
	06/02/2019 09:41	06/02/2019 13:41	06/02/2019 17:41	06/02/2019 21:41	07/02/2019 01:41	07/02/2019 05:41	07/02/2019 09:41				
138	119.6(MW)	119.6(MW)	119.6(MW)	121.9(MW)	121.9(MW)	121.9(MW)	121.9(MW)	06/02/2019 13:41	N	Gearbox and switchgear issues and service	06/02/2019 09:42
	06/02/2019 09:41	06/02/2019 13:41	06/02/2019 17:41	06/02/2019 21:41	07/02/2019 01:41	07/02/2019 05:41	07/02/2019 09:41				
138	121.9(MW)	121.9(MW)	121.9(MW)	121.9(MW)	121.9(MW)	121.9(MW)	121.9(MW)	05/02/2019 16:28	N	Gearbox and switchgear issues	05/02/2019 12:31
	05/02/2019 12:28	05/02/2019 16:28	05/02/2019 20:28	06/02/2019 00:28	06/02/2019 04:28	06/02/2019 08:28	06/02/2019 12:28				
	119.6(MW)	119.6(MW)	119.6(MW)	119.6(MW)	121.9(MW)	121.9(MW)	121.9(MW)			Faults	

Max Farm Production (MW)	Crystal Rig II								Site Capped	Additional Information	Created On
	Expected Max Output (MW)							Estimated End			
	Start	Time 1	Time 2	Time 3	Time 4	Time 5	Time 6				
138	04/02/2019 20:15	05/02/2019 00:15	05/02/2019 04:15	05/02/2019 08:15	05/02/2019 12:15	05/02/2019 16:15	05/02/2019 20:15	05/02/2019 00:15	N		04/02/2019 20:16
138	103.5(MW)	103.5(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	04/02/2019 20:30	N	HV investigations ongoing	04/02/2019 16:30
	04/02/2019 16:30	04/02/2019 20:30	05/02/2019 00:30	05/02/2019 04:30	05/02/2019 08:30	05/02/2019 12:30	05/02/2019 16:30				
138	108.1(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	04/02/2019 16:18	N	HV investigations ongoing.	04/02/2019 12:19
	04/02/2019 12:18	04/02/2019 16:18	04/02/2019 20:18	05/02/2019 00:18	05/02/2019 04:18	05/02/2019 08:18	05/02/2019 12:18				
138	112.7(MW)	112.7(MW)	112.7(MW)	112.7(MW)	112.7(MW)	112.7(MW)	112.7(MW)	03/02/2019 15:34	N	1 turbine remains offline. 10 been affected by circuit 4 grid trip	03/02/2019 13:46
	03/02/2019 11:34	03/02/2019 15:34	03/02/2019 19:34	03/02/2019 23:34	04/02/2019 03:34	04/02/2019 07:34	04/02/2019 11:34				
138	112.7(MW)	112.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	03/02/2019 15:34	N	Turbine in service, 10 tripped 5113 gridvolt lower limit	03/02/2019 12:22
	03/02/2019 11:34	03/02/2019 15:34	03/02/2019 19:34	03/02/2019 23:34	04/02/2019 03:34	04/02/2019 07:34	04/02/2019 11:34				
138	133.4(MW)	133.4(MW)	138(MW)	138(MW)	138(MW)	138(MW)	138(MW)	28/01/2019 20:30	N	Annual service	28/01/2019 12:32
	28/01/2019 12:30	28/01/2019 16:30	28/01/2019 20:30	29/01/2019 00:30	29/01/2019 04:30	29/01/2019 08:30	29/01/2019 12:30				
138	124.2(MW)	124.2(MW)	124.2(MW)	124.2(MW)	124.2(MW)	124.2(MW)	124.2(MW)	18/01/2019 17:00	N	5 x HV trip investigation 1 x gearbox replacement	18/01/2019 13:04
	18/01/2019 13:00	18/01/2019 17:00	18/01/2019 21:00	19/01/2019 01:00	19/01/2019 05:00	19/01/2019 09:00	19/01/2019 13:00				
138	112.7(MW)	112.7(MW)	112.7(MW)	112.7(MW)	112.7(MW)	112.7(MW)	112.7(MW)	17/01/2019 20:13	N	10 turbines - HV trip investigation. 1 turbine offline pending gearbox replacement.	17/01/2019 16:17
	17/01/2019 16:13	17/01/2019 20:13	18/01/2019 00:13	18/01/2019 04:13	18/01/2019 08:13	18/01/2019 12:13	18/01/2019 16:13				
	112.7(MW)	112.7(MW)	112.7(MW)	112.7(MW)	112.7(MW)	112.7(MW)	112.7(MW)			Potential HV issue	

Max Farm Production (MW)	Crystal Rig II								Site Capped	Additional Information	Created On
	Expected Max Output (MW)							Estimated End			
	Start	Time 1	Time 2	Time 3	Time 4	Time 5	Time 6				
138	16/01/2019 16:47	16/01/2019 20:47	17/01/2019 00:47	17/01/2019 04:47	17/01/2019 08:47	17/01/2019 12:47	17/01/2019 16:47	16/01/2019 20:47	N		16/01/2019 16:49
138	115(MW)	-	-	-	-	-	-	14/01/2019 23:59	N	10 x turbines offline	13/01/2019 15:48
	13/01/2019 16:00	-	-	-	-	-	-				
138	112.7(MW)	112.7(MW)	112.7(MW)	112.7(MW)	112.7(MW)	112.7(MW)	138(MW)	13/01/2019 20:00	N	10 turbines offline with earthing fault. 1 turbine offline - service	13/01/2019 00:11
	12/01/2019 20:00	13/01/2019 00:00	13/01/2019 04:00	13/01/2019 08:00	13/01/2019 12:00	13/01/2019 16:00	13/01/2019 20:00				
138	115(MW)	138(MW)	138(MW)	138(MW)	138(MW)	138(MW)	138(MW)	12/01/2019 20:00	N	WTG x 10 in fault condition	12/01/2019 16:38
	12/01/2019 16:00	12/01/2019 20:00	13/01/2019 00:00	13/01/2019 04:00	13/01/2019 08:00	13/01/2019 12:00	13/01/2019 16:00				
138	128.8(MW)	138(MW)	138(MW)	138(MW)	138(MW)	138(MW)	138(MW)	16/12/2018 08:08	N	Faults	16/12/2018 04:08
	16/12/2018 04:08	16/12/2018 08:08	16/12/2018 12:08	16/12/2018 16:08	16/12/2018 20:08	17/12/2018 00:08	17/12/2018 04:08				
138	128.8(MW)	138(MW)	138(MW)	138(MW)	138(MW)	138(MW)	138(MW)	16/12/2018 04:12	N	Faults	16/12/2018 00:13
	16/12/2018 00:12	16/12/2018 04:12	16/12/2018 08:12	16/12/2018 12:12	16/12/2018 16:12	16/12/2018 20:12	17/12/2018 00:12				
138	128.8(MW)	138(MW)	138(MW)	138(MW)	138(MW)	138(MW)	138(MW)	16/12/2018 00:20	N	Faults	15/12/2018 20:21
	15/12/2018 20:20	16/12/2018 00:20	16/12/2018 04:20	16/12/2018 08:20	16/12/2018 12:20	16/12/2018 16:20	16/12/2018 20:20				
138	128.8(MW)	128.8(MW)	138(MW)	138(MW)	138(MW)	138(MW)	138(MW)	21/11/2018 16:20	N	Servicing ongoing.	21/11/2018 08:21
	21/11/2018 08:20	21/11/2018 12:20	21/11/2018 16:20	21/11/2018 20:20	22/11/2018 00:20	22/11/2018 04:20	22/11/2018 08:20				
	115(MW)	115(MW)	133.4(MW)	133.4(MW)	133.4(MW)	133.4(MW)	133.4(MW)			Outage works	

Max Farm Production (MW)	Crystal Rig II								Site Capped	Additional Information	Created On
	Expected Max Output (MW)							Estimated End			
	Start	Time 1	Time 2	Time 3	Time 4	Time 5	Time 6				
138	16/11/2018 09:36	16/11/2018 13:36	16/11/2018 17:36	16/11/2018 21:36	17/11/2018 01:36	17/11/2018 05:36	17/11/2018 09:36	16/11/2018 13:36	N		16/11/2018 09:37
138	112.7(MW)	112.7(MW)	119.6(MW)	119.6(MW)	119.6(MW)	119.6(MW)	119.6(MW)	15/11/2018 16:19	N	HV Issues and service	15/11/2018 12:20
	15/11/2018 12:19	15/11/2018 16:19	15/11/2018 20:19	16/11/2018 00:19	16/11/2018 04:19	16/11/2018 08:19	16/11/2018 12:19				
138	117.3(MW)	117.3(MW)	117.3(MW)	119.6(MW)	119.6(MW)	119.6(MW)	119.6(MW)	15/11/2018 12:34	N	HV Issues and Annual service	15/11/2018 08:35
	15/11/2018 08:34	15/11/2018 12:34	15/11/2018 16:34	15/11/2018 20:34	16/11/2018 00:34	16/11/2018 04:34	16/11/2018 08:34				
138	119.6(MW)	119.6(MW)	119.6(MW)	119.6(MW)	119.6(MW)	119.6(MW)	119.6(MW)	14/11/2018 20:00	N	8x turbines offline due to outage	14/11/2018 16:23
	14/11/2018 16:00	14/11/2018 20:00	15/11/2018 00:00	15/11/2018 04:00	15/11/2018 08:00	15/11/2018 12:00	15/11/2018 16:00				
138	119.6(MW)	119.6(MW)	119.6(MW)	119.6(MW)	119.6(MW)	119.6(MW)	119.6(MW)	13/11/2018 20:30	N	HV works ongoing.	13/11/2018 16:33
	13/11/2018 16:30	13/11/2018 20:30	14/11/2018 00:30	14/11/2018 04:30	14/11/2018 08:30	14/11/2018 12:30	14/11/2018 16:30				
138	94.3(MW)	94.3(MW)	133.4(MW)	133.4(MW)	133.4(MW)	133.4(MW)	133.4(MW)	13/11/2018 16:22	N	HV works	13/11/2018 12:23
	13/11/2018 12:22	13/11/2018 16:22	13/11/2018 20:22	14/11/2018 00:22	14/11/2018 04:22	14/11/2018 08:22	14/11/2018 12:22				
138	117.3(MW)	117.3(MW)	117.3(MW)	131.1(MW)	131.1(MW)	131.1(MW)	131.1(MW)	13/11/2018 13:32	N	Hv works	13/11/2018 09:40
	13/11/2018 09:32	13/11/2018 13:32	13/11/2018 17:32	13/11/2018 21:32	14/11/2018 01:32	14/11/2018 05:32	14/11/2018 09:32				
138	121.9(MW)	121.9(MW)	121.9(MW)	121.9(MW)	121.9(MW)	121.9(MW)	121.9(MW)	12/11/2018 12:30	N	HV works ongoing.	12/11/2018 08:32
	12/11/2018 08:30	12/11/2018 12:30	12/11/2018 16:30	12/11/2018 20:30	13/11/2018 00:30	13/11/2018 04:30	13/11/2018 08:30				
	124.2(MW)	-	-	-	-	-	-			HV Issues	

Max Farm Production (MW)	Crystal Rig II							Estimated End	Site Capped	Additional Information	Created On
	Expected Max Output (MW)										
	Start	Time 1	Time 2	Time 3	Time 4	Time 5	Time 6				
138	08/11/2018 16:05	-	-	-	-	-	-	13/11/2018 17:00	N		08/11/2018 16:05
138	121.9(MW)	121.9(MW)	121.9(MW)	124.2(MW)	124.2(MW)	124.2(MW)	124.2(MW)	08/11/2018 12:46	N	HV Issues and service	08/11/2018 08:47
	08/11/2018 08:46	08/11/2018 12:46	08/11/2018 16:46	08/11/2018 20:46	09/11/2018 00:46	09/11/2018 04:46	09/11/2018 08:46				
138	121.9(MW)	121.9(MW)	121.9(MW)	121.9(MW)	121.9(MW)	121.9(MW)	121.9(MW)	08/11/2018 00:10	N	WTG Faults	07/11/2018 20:09
	07/11/2018 20:10	08/11/2018 00:10	08/11/2018 04:10	08/11/2018 08:10	08/11/2018 12:10	08/11/2018 16:10	08/11/2018 20:10				
138	112.7(MW)	112.7(MW)	112.7(MW)	112.7(MW)	112.7(MW)	112.7(MW)	121.9(MW)	06/11/2018 20:23	N	Removal of HV cable boots inside the switchgear panels followed by the installation of bypass apparatus for the switchgear. 4 turbines in dry out mode.	06/11/2018 16:30
	06/11/2018 16:23	06/11/2018 20:23	07/11/2018 00:23	07/11/2018 04:23	07/11/2018 08:23	07/11/2018 12:23	07/11/2018 16:23				
138	115(MW)	115(MW)	115(MW)	115(MW)	115(MW)	115(MW)	115(MW)	05/11/2018 21:22	N	Removal of HV cable boots inside the switchgear panels followed by the installation of bypass apparatus for the switchgear	05/11/2018 17:23
	05/11/2018 17:22	05/11/2018 21:22	06/11/2018 01:22	06/11/2018 05:22	06/11/2018 09:22	06/11/2018 13:22	06/11/2018 17:22				
138	112.7(MW)	112.7(MW)	138(MW)	138(MW)	138(MW)	138(MW)	138(MW)	05/11/2018 20:23	N	10 Turbines - Removal of HV cable boots inside the switchgear panels followed by the installation of bypass apparatus for the switchgear.	05/11/2018 12:24
	05/11/2018 12:23	05/11/2018 16:23	05/11/2018 20:23	06/11/2018 00:23	06/11/2018 04:23	06/11/2018 08:23	06/11/2018 12:23				
138	115(MW)	-	-	-	-	-	-	05/11/2018 12:00	N	Turbines remain offline due to an ongoing High Voltage issue which affects this string of 10 turbines	04/11/2018 09:10
	04/11/2018 09:00	-	-	-	-	-	-				
138	115(MW)	115(MW)	115(MW)	115(MW)	138(MW)	138(MW)	138(MW)	04/11/2018 12:00	N	10 x turbines offline due to HV issue.	03/11/2018 20:22
	03/11/2018 20:00	04/11/2018 00:00	04/11/2018 04:00	04/11/2018 08:00	04/11/2018 12:00	04/11/2018 16:00	04/11/2018 20:00				
	115(MW)	115(MW)	138(MW)	138(MW)	138(MW)	138(MW)	138(MW)			Turbines offline for maintenance and repair	

Max Farm Production (MW)	Crystal Rig II								Site Capped	Additional Information	Created On
	Expected Max Output (MW)							Estimated End			
	Start	Time 1	Time 2	Time 3	Time 4	Time 5	Time 6				
138	03/11/2018 15:00	03/11/2018 19:00	03/11/2018 23:00	04/11/2018 03:00	04/11/2018 07:00	04/11/2018 11:00	04/11/2018 15:00	03/11/2018 23:00	N		03/11/2018 16:48
138	128.8(MW)	128.8(MW)	138(MW)	138(MW)	138(MW)	138(MW)	138(MW)	16/10/2018 18:00	N	4 WTG's in Maintenance	16/10/2018 11:22
	16/10/2018 10:00	16/10/2018 14:00	16/10/2018 18:00	16/10/2018 22:00	17/10/2018 02:00	17/10/2018 06:00	17/10/2018 10:00				
138	133.4(MW)	133.4(MW)	133.4(MW)	133.4(MW)	138(MW)	138(MW)	138(MW)	18/09/2018 16:22	N	2 turbines offline (faulted)	18/09/2018 00:22
	18/09/2018 00:22	18/09/2018 04:22	18/09/2018 08:22	18/09/2018 12:22	18/09/2018 16:22	18/09/2018 20:22	19/09/2018 00:22				
138	128.8(MW)	128.8(MW)	133.4(MW)	133.4(MW)	133.4(MW)	133.4(MW)	133.4(MW)	26/08/2018 08:09	N		26/08/2018 04:09
	26/08/2018 04:09	26/08/2018 08:09	26/08/2018 12:09	26/08/2018 16:09	26/08/2018 20:09	27/08/2018 00:09	27/08/2018 04:09				
138	128.8(MW)	133.4(MW)	133.4(MW)	133.4(MW)	133.4(MW)	133.4(MW)	133.4(MW)	26/08/2018 04:20	N		26/08/2018 00:20
	26/08/2018 00:20	26/08/2018 04:20	26/08/2018 08:20	26/08/2018 12:20	26/08/2018 16:20	26/08/2018 20:20	27/08/2018 00:20				
138	124.2(MW)	124.2(MW)	124.2(MW)	138(MW)	138(MW)	138(MW)	138(MW)	25/08/2018 12:08	N	Faults/repairs	25/08/2018 00:08
	25/08/2018 00:08	25/08/2018 04:08	25/08/2018 08:08	25/08/2018 12:08	25/08/2018 16:08	25/08/2018 20:08	26/08/2018 00:08				
138	124.2(MW)	124.2(MW)	124.2(MW)	138(MW)	138(MW)	138(MW)	138(MW)	25/08/2018 01:54	N	^ turbines offline with faults	24/08/2018 13:54
	24/08/2018 13:54	24/08/2018 17:54	24/08/2018 21:54	25/08/2018 01:54	25/08/2018 05:54	25/08/2018 09:54	25/08/2018 13:54				
138	124.2(MW)	124.2(MW)	124.2(MW)	138(MW)	138(MW)	138(MW)	138(MW)	25/08/2018 01:41	N	Turbinesx offline with faults	24/08/2018 13:42
	24/08/2018 13:41	24/08/2018 17:41	24/08/2018 21:41	25/08/2018 01:41	25/08/2018 05:41	25/08/2018 09:41	25/08/2018 13:41				
	112.7(MW)	112.7(MW)	112.7(MW)	112.7(MW)	112.7(MW)	112.7(MW)	112.7(MW)			all off for HV maintenance.	

Max Farm Production (MW)	Crystal Rig II								Site Capped	Additional Information	Created On
	Expected Max Output (MW)							Estimated End			
	Start	Time 1	Time 2	Time 3	Time 4	Time 5	Time 6				
138	23/08/2018 16:15	23/08/2018 20:15	24/08/2018 00:15	24/08/2018 04:15	24/08/2018 08:15	24/08/2018 12:15	24/08/2018 16:15	23/08/2018 20:15	N		23/08/2018 16:16
138	110.4(MW)	110.4(MW)	110.4(MW)	110.4(MW)	138(MW)	138(MW)	138(MW)	23/08/2018 16:01	N	11 turbines offline ongoing HV works. 1 turbine faulted (Turbine 19)	23/08/2018 00:03
	23/08/2018 00:01	23/08/2018 04:01	23/08/2018 08:01	23/08/2018 12:01	23/08/2018 16:01	23/08/2018 20:01	24/08/2018 00:01				
138	112.7(MW)	112.7(MW)	112.7(MW)	112.7(MW)	112.7(MW)	112.7(MW)	138(MW)	23/08/2018 16:30	N	11 turbines offline ongoing HV works	22/08/2018 16:31
	22/08/2018 16:30	22/08/2018 20:30	23/08/2018 00:30	23/08/2018 04:30	23/08/2018 08:30	23/08/2018 12:30	23/08/2018 16:30				
138	87.4(MW)	87.4(MW)	87.4(MW)	138(MW)	138(MW)	138(MW)	138(MW)	22/08/2018 20:29	N	22 turbines, ongoing HV maintenance	22/08/2018 08:30
	22/08/2018 08:29	22/08/2018 12:29	22/08/2018 16:29	22/08/2018 20:29	23/08/2018 00:29	23/08/2018 04:29	23/08/2018 08:29				
138	110.4(MW)	110.4(MW)	110.4(MW)	110.4(MW)	138(MW)	138(MW)	138(MW)	22/08/2018 16:20	N	11 turbines offline planned HV maintenance. 1 turbine faulted (T17)	22/08/2018 00:20
	22/08/2018 00:20	22/08/2018 04:20	22/08/2018 08:20	22/08/2018 12:20	22/08/2018 16:20	22/08/2018 20:20	23/08/2018 00:20				
138	112.7(MW)	112.7(MW)	112.7(MW)	112.7(MW)	112.7(MW)	112.7(MW)	112.7(MW)	21/08/2018 20:28	N	11 turbines offline planned HV maintenance	21/08/2018 16:28
	21/08/2018 16:28	21/08/2018 20:28	22/08/2018 00:28	22/08/2018 04:28	22/08/2018 08:28	22/08/2018 12:28	22/08/2018 16:28				
138	89.7(MW)	89.7(MW)	89.7(MW)	138(MW)	138(MW)	138(MW)	138(MW)	21/08/2018 20:04	N	21 Turbines offline due to Planned HV maintenance	21/08/2018 08:05
	21/08/2018 08:04	21/08/2018 12:04	21/08/2018 16:04	21/08/2018 20:04	22/08/2018 00:04	22/08/2018 04:04	22/08/2018 08:04				
138	112.7(MW)	112.7(MW)	112.7(MW)	112.7(MW)	138(MW)	138(MW)	138(MW)	21/08/2018 16:00	N	10 turbines offline HV maintenance and HV Switchgear fault (T19)	21/08/2018 00:26
	21/08/2018 00:00	21/08/2018 04:00	21/08/2018 08:00	21/08/2018 12:00	21/08/2018 16:00	21/08/2018 20:00	22/08/2018 00:00				
	115(MW)	115(MW)	115(MW)	115(MW)	115(MW)	115(MW)	138(MW)			X Boundary isolations for HV 4 yearly maintenance on array 3	

Max Farm Production (MW)	Crystal Rig II								Site Capped	Additional Information	Created On
	Expected Max Output (MW)							Estimated End			
	Start	Time 1	Time 2	Time 3	Time 4	Time 5	Time 6				
138	20/08/2018 16:00	20/08/2018 20:00	21/08/2018 00:00	21/08/2018 04:00	21/08/2018 08:00	21/08/2018 12:00	21/08/2018 16:00	21/08/2018 16:00	N		20/08/2018 16:34
138	115(MW)	115(MW)	115(MW)	138(MW)	138(MW)	138(MW)	138(MW)	20/08/2018 20:18	N	10 turbines offline HV maintenance	20/08/2018 08:19
	20/08/2018 08:18	20/08/2018 12:18	20/08/2018 16:18	20/08/2018 20:18	21/08/2018 00:18	21/08/2018 04:18	21/08/2018 08:18				
138	115(MW)	115(MW)	115(MW)	115(MW)	115(MW)	115(MW)	138(MW)	17/08/2018 20:13	N	HV Maintenance	16/08/2018 20:13
	16/08/2018 20:13	17/08/2018 00:13	17/08/2018 04:13	17/08/2018 08:13	17/08/2018 12:13	17/08/2018 16:13	17/08/2018 20:13				
138	115(MW)	115(MW)	138(MW)	138(MW)	138(MW)	138(MW)	138(MW)	16/08/2018 20:23	N	10 turbines offline due to HV maintenance	16/08/2018 12:23
	16/08/2018 12:23	16/08/2018 16:23	16/08/2018 20:23	17/08/2018 00:23	17/08/2018 04:23	17/08/2018 08:23	17/08/2018 12:23				
138	110.4(MW)	110.4(MW)	110.4(MW)	110.4(MW)	110.4(MW)	110.4(MW)	110.4(MW)	15/08/2018 20:22	N	HV works ongoing	15/08/2018 16:23
	15/08/2018 16:22	15/08/2018 20:22	16/08/2018 00:22	16/08/2018 04:22	16/08/2018 08:22	16/08/2018 12:22	16/08/2018 16:22				
138	94.3(MW)	94.3(MW)	138(MW)	138(MW)	138(MW)	138(MW)	138(MW)	15/08/2018 20:12	N	19 off for HV works	15/08/2018 12:13
	15/08/2018 12:12	15/08/2018 16:12	15/08/2018 20:12	16/08/2018 00:12	16/08/2018 04:12	16/08/2018 08:12	16/08/2018 12:12				
138	112.7(MW)	112.7(MW)	112.7(MW)	112.7(MW)	138(MW)	138(MW)	138(MW)	15/08/2018 20:00	N	10 turbines offline HV maintenance, 1 turbine offline UPS Bypass error	15/08/2018 04:08
	15/08/2018 04:00	15/08/2018 08:00	15/08/2018 12:00	15/08/2018 16:00	15/08/2018 20:00	16/08/2018 00:00	16/08/2018 04:00				
138	115(MW)	115(MW)	115(MW)	115(MW)	138(MW)	138(MW)	138(MW)	15/08/2018 16:00	N	10 turbines offline HV works on array 2	15/08/2018 00:10
	15/08/2018 00:00	15/08/2018 04:00	15/08/2018 08:00	15/08/2018 12:00	15/08/2018 16:00	15/08/2018 20:00	16/08/2018 00:00				
	115(MW)	115(MW)	115(MW)	115(MW)	115(MW)	115(MW)	138(MW)			10 Turbines offline HV Maintenance	

Max Farm Production (MW)	Crystal Rig II								Site Capped	Additional Information	Created On
	Expected Max Output (MW)							Estimated End			
	Start	Time 1	Time 2	Time 3	Time 4	Time 5	Time 6				
138	14/08/2018 17:00	14/08/2018 21:00	15/08/2018 01:00	15/08/2018 05:00	15/08/2018 09:00	15/08/2018 13:00	15/08/2018 17:00	15/08/2018 17:00	N		14/08/2018 20:13
138	115(MW)	-	-	-	-	-	-	15/08/2018 17:00	N	HV maintenance on Array 2	14/08/2018 14:28
	14/08/2018 14:30	-	-	-	-	-	-				
138	94.3(MW)	94.3(MW)	94.3(MW)	138(MW)	138(MW)	138(MW)	138(MW)	14/08/2018 20:00	N	HV works on site	14/08/2018 08:19
	14/08/2018 08:00	14/08/2018 12:00	14/08/2018 16:00	14/08/2018 20:00	15/08/2018 00:00	15/08/2018 04:00	15/08/2018 08:00				
138	117.3(MW)	117.3(MW)	117.3(MW)	117.3(MW)	117.3(MW)	117.3(MW)	117.3(MW)	13/08/2018 21:00	N	X Boundary isolations for HV 4 yearly maintenance on array A	13/08/2018 17:13
	13/08/2018 17:00	13/08/2018 21:00	14/08/2018 01:00	14/08/2018 05:00	14/08/2018 09:00	14/08/2018 13:00	14/08/2018 17:00				
138	117.3(MW)	117.3(MW)	138(MW)	138(MW)	138(MW)	138(MW)	138(MW)	13/08/2018 20:00	N	offline for HV work	13/08/2018 12:21
	13/08/2018 12:00	13/08/2018 16:00	13/08/2018 20:00	14/08/2018 00:00	14/08/2018 04:00	14/08/2018 08:00	14/08/2018 12:00				
138	117.3(MW)	117.3(MW)	138(MW)	138(MW)	138(MW)	138(MW)	138(MW)	13/08/2018 20:12	N	T1-9 offline HV isolations for HV works	13/08/2018 12:13
	13/08/2018 12:12	13/08/2018 16:12	13/08/2018 20:12	14/08/2018 00:12	14/08/2018 04:12	14/08/2018 08:12	14/08/2018 12:12				
138	29.9(MW)	29.9(MW)	138(MW)	138(MW)	138(MW)	138(MW)	138(MW)	12/08/2018 12:30	N	HV Maintenance complete. 46 turbines currently remain in converter drying mode. Turbines will automatically restart when ready. 1 turbine faulted.	12/08/2018 04:57
	12/08/2018 04:30	12/08/2018 08:30	12/08/2018 12:30	12/08/2018 16:30	12/08/2018 20:30	13/08/2018 00:30	13/08/2018 04:30				
138	32.2(MW)	32.2(MW)	138(MW)	138(MW)	138(MW)	138(MW)	138(MW)	12/08/2018 04:30	N	HV Maintenance complete. 46 turbines currently remain in converter drying mode approx. return to service 00:00 12/08/2018	11/08/2018 20:56
	11/08/2018 20:30	12/08/2018 00:30	12/08/2018 04:30	12/08/2018 08:30	12/08/2018 12:30	12/08/2018 16:30	12/08/2018 20:30				
	0(MW)	0(MW)	0(MW)	0(MW)	0(MW)	0(MW)	0(MW)			HV Maintenance complete turbines in converter drying mode	

Max Farm Production (MW)	Crystal Rig II								Site Capped	Additional Information	Created On
	Expected Max Output (MW)							Estimated End			
	Start	Time 1	Time 2	Time 3	Time 4	Time 5	Time 6				
138	10/08/2018 17:00	10/08/2018 21:00	11/08/2018 01:00	11/08/2018 05:00	11/08/2018 09:00	11/08/2018 13:00	11/08/2018 17:00	10/08/2018 21:00	N	approx return to service 17:00 11/08/2018	10/08/2018 16:04
0	0(MW)	-	-	-	-	-	-	10/08/2018 17:00	Y	HV maintenance. : HV maintenance.	06/08/2018 08:37
	06/08/2018 08:35	-	-	-	-	-	-				
138	119.6(MW)	119.6(MW)	119.6(MW)	119.6(MW)	119.6(MW)	124.2(MW)	138(MW)	26/07/2018 00:00	N	faulted and discharge testing ongoing	25/07/2018 04:27
	25/07/2018 00:00	25/07/2018 04:00	25/07/2018 08:00	25/07/2018 12:00	25/07/2018 16:00	25/07/2018 20:00	26/07/2018 00:00				
138	124.2(MW)	-	-	-	-	-	-	25/07/2018 18:00	N	Off due to partial discharge of T22 switchgear. Cable jointer to attend site to carry out cable re-terminations. MES provisionally booked to attend site 25.07.2018	23/07/2018 17:39
	23/07/2018 17:00	-	-	-	-	-	-				
138	121.9(MW)	133.4(MW)	138(MW)	138(MW)	138(MW)	138(MW)	138(MW)	23/07/2018 20:00	N	HV Inspections and turbine servicing.	23/07/2018 12:27
	23/07/2018 12:00	23/07/2018 16:00	23/07/2018 20:00	24/07/2018 00:00	24/07/2018 04:00	24/07/2018 08:00	24/07/2018 12:00				
138	128.8(MW)	128.8(MW)	133.4(MW)	138(MW)	138(MW)	138(MW)	138(MW)	12/07/2018 00:09	N	2 turbines in warmup mode, 2 turbines in service	11/07/2018 12:09
	11/07/2018 12:09	11/07/2018 16:09	11/07/2018 20:09	12/07/2018 00:09	12/07/2018 04:09	12/07/2018 08:09	12/07/2018 12:09				
138	126.5(MW)	126.5(MW)	126.5(MW)	131.1(MW)	131.1(MW)	131.1(MW)	131.1(MW)	10/07/2018 16:00	N	faulted turbines	10/07/2018 12:06
	10/07/2018 12:00	10/07/2018 16:00	10/07/2018 20:00	11/07/2018 00:00	11/07/2018 04:00	11/07/2018 08:00	11/07/2018 12:00				
138	128.8(MW)	131.1(MW)	131.1(MW)	131.1(MW)	131.1(MW)	131.1(MW)	131.1(MW)	09/07/2018 16:28	N	Repair/faults	09/07/2018 12:29
	09/07/2018 12:28	09/07/2018 16:28	09/07/2018 20:28	10/07/2018 00:28	10/07/2018 04:28	10/07/2018 08:28	10/07/2018 12:28				
	117.3(MW)	117.3(MW)	117.3(MW)	117.3(MW)	131.1(MW)	131.1(MW)	131.1(MW)			5 turbines in generating heating mode. 4 turbines general	

Max Farm Production (MW)	Crystal Rig II								Site Capped	Additional Information	Created On
	Expected Max Output (MW)							Estimated End			
	Start	Time 1	Time 2	Time 3	Time 4	Time 5	Time 6				
138	09/07/2018 00:00	09/07/2018 04:00	09/07/2018 08:00	09/07/2018 12:00	09/07/2018 16:00	09/07/2018 20:00	10/07/2018 00:00	09/07/2018 04:00	N	maintenance and faults.	09/07/2018 00:09
138	119.6(MW)	119.6(MW)	119.6(MW)	119.6(MW)	119.6(MW)	119.6(MW)	131.1(MW)	08/07/2018 20:00	N	5 in dry up mode 3 faulted	08/07/2018 16:11
	08/07/2018 16:00	08/07/2018 20:00	09/07/2018 00:00	09/07/2018 04:00	09/07/2018 08:00	09/07/2018 12:00	09/07/2018 16:00				
138	119.6(MW)	119.6(MW)	119.6(MW)	119.6(MW)	131.1(MW)	131.1(MW)	131.1(MW)	08/07/2018 04:00	N	5 in converter drying mode, 3 faulted	08/07/2018 05:58
	08/07/2018 00:00	08/07/2018 04:00	08/07/2018 08:00	08/07/2018 12:00	08/07/2018 16:00	08/07/2018 20:00	09/07/2018 00:00				
138	117.3(MW)	117.3(MW)	131.1(MW)	131.1(MW)	131.1(MW)	131.1(MW)	131.1(MW)	07/07/2018 20:00	N	6 converter drying 3 faulted	07/07/2018 16:15
	07/07/2018 16:00	07/07/2018 20:00	08/07/2018 00:00	08/07/2018 04:00	08/07/2018 08:00	08/07/2018 12:00	08/07/2018 16:00				
138	110.4(MW)	110.4(MW)	110.4(MW)	110.4(MW)	128.8(MW)	131.1(MW)	131.1(MW)	07/07/2018 04:00	N	8 in warm up after HV 3 long term fault 1 faulted	07/07/2018 08:37
	07/07/2018 00:00	07/07/2018 04:00	07/07/2018 08:00	07/07/2018 12:00	07/07/2018 16:00	07/07/2018 20:00	08/07/2018 00:00				
138	110.4(MW)	110.4(MW)	110.4(MW)	110.4(MW)	110.4(MW)	110.4(MW)	110.4(MW)	06/07/2018 00:00	N	HV works and general maintenance	05/07/2018 20:15
	05/07/2018 20:00	06/07/2018 00:00	06/07/2018 04:00	06/07/2018 08:00	06/07/2018 12:00	06/07/2018 16:00	06/07/2018 20:00				
138	105.8(MW)	105.8(MW)	105.8(MW)	105.8(MW)	105.8(MW)	105.8(MW)	105.8(MW)	05/07/2018 00:00	N	HV works and general maintenance.	04/07/2018 20:12
	04/07/2018 20:00	05/07/2018 00:00	05/07/2018 04:00	05/07/2018 08:00	05/07/2018 12:00	05/07/2018 16:00	05/07/2018 20:00				
138	103.5(MW)	103.5(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	04/07/2018 16:47	N	15 turbines offline HV works ongoing	04/07/2018 12:48
	04/07/2018 12:47	04/07/2018 16:47	04/07/2018 20:47	05/07/2018 00:47	05/07/2018 04:47	05/07/2018 08:47	05/07/2018 12:47				
	105.8(MW)	105.8(MW)	105.8(MW)	105.8(MW)	105.8(MW)	128.8(MW)	128.8(MW)			14 turbines offline with faults	

Max Farm Production (MW)	Crystal Rig II								Site Capped	Additional Information	Created On
	Expected Max Output (MW)							Estimated End			
	Start	Time 1	Time 2	Time 3	Time 4	Time 5	Time 6				
138	03/07/2018 20:16	04/07/2018 00:16	04/07/2018 04:16	04/07/2018 08:16	04/07/2018 12:16	04/07/2018 16:16	04/07/2018 20:16	04/07/2018 00:16	N		03/07/2018 20:16
138	105.8(MW)	105.8(MW)	105.8(MW)	105.8(MW)	105.8(MW)	128.8(MW)	128.8(MW)	04/07/2018 00:08	N	14 turbines offline with faults	03/07/2018 20:09
	03/07/2018 20:08	04/07/2018 00:08	04/07/2018 04:08	04/07/2018 08:08	04/07/2018 12:08	04/07/2018 16:08	04/07/2018 20:08				
138	110.4(MW)	110.4(MW)	110.4(MW)	110.4(MW)	128.8(MW)	128.8(MW)	128.8(MW)	03/07/2018 12:21	N	8 HV Works, 4 Turbine faults	03/07/2018 08:23
	03/07/2018 08:21	03/07/2018 12:21	03/07/2018 16:21	03/07/2018 20:21	04/07/2018 00:21	04/07/2018 04:21	04/07/2018 08:21				
138	110.4(MW)	131.1(MW)	131.1(MW)	131.1(MW)	131.1(MW)	131.1(MW)	131.1(MW)	02/07/2018 16:53	N	8 Offline turbines, HV Works, 1xService,3xFaults	02/07/2018 12:55
	02/07/2018 12:53	02/07/2018 16:53	02/07/2018 20:53	03/07/2018 00:53	03/07/2018 04:53	03/07/2018 08:53	03/07/2018 12:53				
138	126.5(MW)	126.5(MW)	126.5(MW)	126.5(MW)	135.7(MW)	135.7(MW)	135.7(MW)	02/07/2018 08:09	N	5 Turbines offline with faults.	02/07/2018 04:09
	02/07/2018 04:09	02/07/2018 08:09	02/07/2018 12:09	02/07/2018 16:09	02/07/2018 20:09	03/07/2018 00:09	03/07/2018 04:09				
138	126.5(MW)	126.5(MW)	126.5(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	02/07/2018 08:08	N	% turbines offline with faults.	02/07/2018 04:08
	02/07/2018 04:08	02/07/2018 08:08	02/07/2018 12:08	02/07/2018 16:08	02/07/2018 20:08	03/07/2018 00:08	03/07/2018 04:08				
138	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	135.7(MW)	02/07/2018 00:10	N	4 turbines offline with faults.	01/07/2018 20:11
	01/07/2018 20:10	02/07/2018 00:10	02/07/2018 04:10	02/07/2018 08:10	02/07/2018 12:10	02/07/2018 16:10	02/07/2018 20:10				
138	126.5(MW)	126.5(MW)	126.5(MW)	126.5(MW)	128.8(MW)	128.8(MW)	128.8(MW)	01/07/2018 00:11	N	WTG faults	30/06/2018 20:12
	30/06/2018 20:11	01/07/2018 00:11	01/07/2018 04:11	01/07/2018 08:11	01/07/2018 12:11	01/07/2018 16:11	01/07/2018 20:11				
	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)				

Max Farm Production (MW)	Crystal Rig II								Site Capped	Additional Information	Created On
	Expected Max Output (MW)							Estimated End			
	Start	Time 1	Time 2	Time 3	Time 4	Time 5	Time 6				
138	30/06/2018 16:16	30/06/2018 20:16	01/07/2018 00:16	01/07/2018 04:16	01/07/2018 08:16	01/07/2018 12:16	01/07/2018 16:16	30/06/2018 20:16	N		30/06/2018 16:22
138	126.5(MW)	126.5(MW)	126.5(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	30/06/2018 08:08	N	5 turbines offline with various faults.	30/06/2018 04:10
	30/06/2018 04:08	30/06/2018 08:08	30/06/2018 12:08	30/06/2018 16:08	30/06/2018 20:08	01/07/2018 00:08	01/07/2018 04:08				
138	124.2(MW)	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	29/06/2018 16:43	N		29/06/2018 12:44
	29/06/2018 12:43	29/06/2018 16:43	29/06/2018 20:43	30/06/2018 00:43	30/06/2018 04:43	30/06/2018 08:43	30/06/2018 12:43				
138	124.2(MW)	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	28/06/2018 16:00	N	Turbines 17, 21, 33, 53, 59 and 60, Offline/general maintenance.	28/06/2018 12:05
	28/06/2018 12:00	28/06/2018 16:00	28/06/2018 20:00	29/06/2018 00:00	29/06/2018 04:00	29/06/2018 08:00	29/06/2018 12:00				
138	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	131.1(MW)	131.1(MW)	131.1(MW)	27/06/2018 21:00	N	T21, 59 and 60 offline. T33 faulted.	27/06/2018 17:27
	27/06/2018 17:00	27/06/2018 21:00	28/06/2018 01:00	28/06/2018 05:00	28/06/2018 09:00	28/06/2018 13:00	28/06/2018 17:00				
138	126.5(MW)	131.1(MW)	131.1(MW)	131.1(MW)	131.1(MW)	131.1(MW)	131.1(MW)	27/06/2018 16:20	N	T21, T59 and T60 offline. T17 and T33 general maintenance	27/06/2018 12:27
	27/06/2018 12:20	27/06/2018 16:20	27/06/2018 20:20	28/06/2018 00:20	28/06/2018 04:20	28/06/2018 08:20	28/06/2018 12:20				
138	128.8(MW)	128.8(MW)	128.8(MW)	131.1(MW)	131.1(MW)	131.1(MW)	131.1(MW)	27/06/2018 12:30	N	T21, T59 and T60 offline. T44 general maintenance	27/06/2018 08:26
	27/06/2018 08:30	27/06/2018 12:30	27/06/2018 16:30	27/06/2018 20:30	28/06/2018 00:30	28/06/2018 04:30	28/06/2018 08:30				
138	128.8(MW)	128.8(MW)	131.1(MW)	131.1(MW)	131.1(MW)	131.1(MW)	131.1(MW)	26/06/2018 16:00	N	Turbines are offline for Maintenance and Repair	26/06/2018 12:26
	26/06/2018 12:00	26/06/2018 16:00	26/06/2018 20:00	27/06/2018 00:00	27/06/2018 04:00	27/06/2018 08:00	27/06/2018 12:00				
	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	131.1(MW)	131.1(MW)	131.1(MW)			ongoing faults	

Max Farm Production (MW)	Crystal Rig II								Site Capped	Additional Information	Created On
	Expected Max Output (MW)							Estimated End			
	Start	Time 1	Time 2	Time 3	Time 4	Time 5	Time 6				
138	25/06/2018 20:00	26/06/2018 00:00	26/06/2018 04:00	26/06/2018 08:00	26/06/2018 12:00	26/06/2018 16:00	26/06/2018 20:00	26/06/2018 00:00	N		25/06/2018 20:17
138	126.5(MW)	131.1(MW)	131.1(MW)	131.1(MW)	131.1(MW)	131.1(MW)	131.1(MW)	25/06/2018 16:22	N	T21, 59 and 60 offline. T50 and T51 general maintenance.	25/06/2018 12:24
	25/06/2018 12:22	25/06/2018 16:22	25/06/2018 20:22	26/06/2018 00:22	26/06/2018 04:22	26/06/2018 08:22	26/06/2018 12:22				
138	128.8(MW)	131.1(MW)	131.1(MW)	131.1(MW)	131.1(MW)	131.1(MW)	131.1(MW)	25/06/2018 08:08	N	Faults/repair	25/06/2018 04:09
	25/06/2018 04:08	25/06/2018 08:08	25/06/2018 12:08	25/06/2018 16:08	25/06/2018 20:08	26/06/2018 00:08	26/06/2018 04:08				
138	126.5(MW)	131.1(MW)	131.1(MW)	131.1(MW)	131.1(MW)	131.1(MW)	131.1(MW)	24/06/2018 16:35	N	WTG faults x 3, WTG Maintenance x 2	24/06/2018 12:36
	24/06/2018 12:35	24/06/2018 16:35	24/06/2018 20:35	25/06/2018 00:35	25/06/2018 04:35	25/06/2018 08:35	25/06/2018 12:35				
138	128.8(MW)	131.1(MW)	131.1(MW)	131.1(MW)	131.1(MW)	131.1(MW)	131.1(MW)	23/06/2018 16:10	N	WTG faults x 3, WTG service x 1	23/06/2018 12:10
	23/06/2018 12:10	23/06/2018 16:10	23/06/2018 20:10	24/06/2018 00:10	24/06/2018 04:10	24/06/2018 08:10	24/06/2018 12:10				
138	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	131.1(MW)	131.1(MW)	22/06/2018 04:06	N	Faults/maintenance	22/06/2018 00:06
	22/06/2018 00:06	22/06/2018 04:06	22/06/2018 08:06	22/06/2018 12:06	22/06/2018 16:06	22/06/2018 20:06	23/06/2018 00:06				
138	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	131.1(MW)	22/06/2018 00:30	N	Maintenance/faults	21/06/2018 20:31
	21/06/2018 20:30	22/06/2018 00:30	22/06/2018 04:30	22/06/2018 08:30	22/06/2018 12:30	22/06/2018 16:30	22/06/2018 20:30				
138	128.8(MW)	128.8(MW)	131.1(MW)	131.1(MW)	131.1(MW)	131.1(MW)	131.1(MW)	21/06/2018 16:46	N	1 turbine being inspected, 3 off longer term.	21/06/2018 12:47
	21/06/2018 12:46	21/06/2018 16:46	21/06/2018 20:46	22/06/2018 00:46	22/06/2018 04:46	22/06/2018 08:46	22/06/2018 12:46				
	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	131.1(MW)	131.1(MW)				

Max Farm Production (MW)	Crystal Rig II								Site Capped	Additional Information	Created On
	Expected Max Output (MW)							Estimated End			
	Start	Time 1	Time 2	Time 3	Time 4	Time 5	Time 6				
138	20/06/2018 16:10	20/06/2018 20:10	21/06/2018 00:10	21/06/2018 04:10	21/06/2018 08:10	21/06/2018 12:10	21/06/2018 16:10	20/06/2018 20:10	N		20/06/2018 16:12
138	112.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	20/06/2018 16:46	N	HV investigation	20/06/2018 12:47
	20/06/2018 12:46	20/06/2018 16:46	20/06/2018 20:46	21/06/2018 00:46	21/06/2018 04:46	21/06/2018 08:46	21/06/2018 12:46				
138	131.1(MW)	-	-	-	-	-	-	29/06/2018 00:00	N	3 x WTG's in fault condition	19/06/2018 15:47
	19/06/2018 15:00	-	-	-	-	-	-				
138	131.1(MW)	-	-	-	-	-	-	29/06/2018 00:00	N	3 x WTG's in fault condition	19/06/2018 15:30
	19/06/2018 15:00	-	-	-	-	-	-				
138	128.8(MW)	128.8(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	17/06/2018 16:19	N	2 turbines being serviced. 2 Turbines faulted	17/06/2018 12:20
	17/06/2018 12:19	17/06/2018 16:19	17/06/2018 20:19	18/06/2018 00:19	18/06/2018 04:19	18/06/2018 08:19	18/06/2018 12:19				
138	128.8(MW)	128.8(MW)	128.8(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	15/06/2018 12:52	N	Service ongoing	15/06/2018 08:53
	15/06/2018 08:52	15/06/2018 12:52	15/06/2018 16:52	15/06/2018 20:52	16/06/2018 00:52	16/06/2018 04:52	16/06/2018 08:52				
138	128.8(MW)	128.8(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	12/06/2018 16:15	N	Service	12/06/2018 12:16
	12/06/2018 12:15	12/06/2018 16:15	12/06/2018 20:15	13/06/2018 00:15	13/06/2018 04:15	13/06/2018 08:15	13/06/2018 12:15				
138	128.8(MW)	128.8(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	08/06/2018 16:31	N	4 turbines offline - 3 for maintenance and 1 with ongoing HV issues	08/06/2018 12:32
	08/06/2018 12:31	08/06/2018 16:31	08/06/2018 20:31	09/06/2018 00:31	09/06/2018 04:31	09/06/2018 08:31	09/06/2018 12:31				
	128.8(MW)	128.8(MW)	138(MW)	138(MW)	138(MW)	138(MW)	138(MW)			Turbines offline for Maintenance and Repair	

Max Farm Production (MW)	Crystal Rig II								Site Capped	Additional Information	Created On
	Expected Max Output (MW)							Estimated End			
	Start	Time 1	Time 2	Time 3	Time 4	Time 5	Time 6				
138	08/06/2018 08:30	08/06/2018 12:30	08/06/2018 16:30	08/06/2018 20:30	09/06/2018 00:30	09/06/2018 04:30	09/06/2018 08:30	08/06/2018 16:30	N		08/06/2018 08:48
138	128.8(MW)	128.8(MW)	128.8(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	05/06/2018 12:19	N	Service/repairs	05/06/2018 08:20
	05/06/2018 08:19	05/06/2018 12:19	05/06/2018 16:19	05/06/2018 20:19	06/06/2018 00:19	06/06/2018 04:19	06/06/2018 08:19				
138	128.8(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	01/06/2018 16:32	N	Faults/service	01/06/2018 12:32
	01/06/2018 12:32	01/06/2018 16:32	01/06/2018 20:32	02/06/2018 00:32	02/06/2018 04:32	02/06/2018 08:32	02/06/2018 12:32				
138	124.2(MW)	128.8(MW)	128.8(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	29/05/2018 12:00	N	general maintenance/servicing on turbines. T21 ongoing HV issues	29/05/2018 08:23
	29/05/2018 08:00	29/05/2018 12:00	29/05/2018 16:00	29/05/2018 20:00	30/05/2018 00:00	30/05/2018 04:00	30/05/2018 08:00				
138	126.5(MW)	126.5(MW)	133.4(MW)	133.4(MW)	133.4(MW)	133.4(MW)	133.4(MW)	25/05/2018 12:25	N	3 x service 1 x blade repairs 1 x HV issues	25/05/2018 08:27
	25/05/2018 08:25	25/05/2018 12:25	25/05/2018 16:25	25/05/2018 20:25	26/05/2018 00:25	26/05/2018 04:25	26/05/2018 08:25				
138	128.8(MW)	128.8(MW)	133.4(MW)	133.4(MW)	133.4(MW)	133.4(MW)	133.4(MW)	24/05/2018 12:32	N	2 turbines offline with faults, 2 being serviced.	24/05/2018 08:32
	24/05/2018 08:32	24/05/2018 12:32	24/05/2018 16:32	24/05/2018 20:32	25/05/2018 00:32	25/05/2018 04:32	25/05/2018 08:32				
138	128.8(MW)	128.8(MW)	128.8(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	22/05/2018 12:00	N	turbines faulted and 1 in long term stop	22/05/2018 08:51
	22/05/2018 08:00	22/05/2018 12:00	22/05/2018 16:00	22/05/2018 20:00	23/05/2018 00:00	23/05/2018 04:00	23/05/2018 08:00				
138	128.8(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	17/05/2018 16:18	N	WTG Maintenance	17/05/2018 12:18
	17/05/2018 12:18	17/05/2018 16:18	17/05/2018 20:18	18/05/2018 00:18	18/05/2018 04:18	18/05/2018 08:18	18/05/2018 12:18				
	128.8(MW)	128.8(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)			WTG maintenance	

Max Farm Production (MW)	Crystal Rig II								Site Capped	Additional Information	Created On
	Expected Max Output (MW)							Estimated End			
	Start	Time 1	Time 2	Time 3	Time 4	Time 5	Time 6				
138	16/05/2018 12:07	16/05/2018 16:07	16/05/2018 20:07	17/05/2018 00:07	17/05/2018 04:07	17/05/2018 08:07	17/05/2018 12:07	16/05/2018 16:07	N		16/05/2018 12:07
138	126.5(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	15/05/2018 16:13	N	WTG service works	15/05/2018 12:13
	15/05/2018 12:13	15/05/2018 16:13	15/05/2018 20:13	16/05/2018 00:13	16/05/2018 04:13	16/05/2018 08:13	16/05/2018 12:13				
138	128.8(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	14/05/2018 16:20	N	WTG maintenance underway.	14/05/2018 12:20
	14/05/2018 12:20	14/05/2018 16:20	14/05/2018 20:20	15/05/2018 00:20	15/05/2018 04:20	15/05/2018 08:20	15/05/2018 12:20				
138	126.5(MW)	126.5(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	08/05/2018 16:19	N	1 x offline 4 x service	08/05/2018 12:19
	08/05/2018 12:19	08/05/2018 16:19	08/05/2018 20:19	09/05/2018 00:19	09/05/2018 04:19	09/05/2018 08:19	09/05/2018 12:19				
138	128.8(MW)	131.1(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	07/05/2018 16:40	N	Annual maintenance x 3, 1 x offline	07/05/2018 12:44
	07/05/2018 12:40	07/05/2018 16:40	07/05/2018 20:40	08/05/2018 00:40	08/05/2018 04:40	08/05/2018 08:40	08/05/2018 12:40				
138	128.8(MW)	128.8(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	04/05/2018 16:37	N	3 x turbines in service	04/05/2018 12:38
	04/05/2018 12:37	04/05/2018 16:37	04/05/2018 20:37	05/05/2018 00:37	05/05/2018 04:37	05/05/2018 08:37	05/05/2018 12:37				
138	128.8(MW)	128.8(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	03/05/2018 16:25	N	4 turbines offline - 3 for stat inspections and service, 1 with ongoing HV issues	03/05/2018 12:27
	03/05/2018 12:25	03/05/2018 16:25	03/05/2018 20:25	04/05/2018 00:25	04/05/2018 04:25	04/05/2018 08:25	04/05/2018 12:25				
138	128.8(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	02/05/2018 16:29	N	3 turbines being serviced - one off long term	02/05/2018 12:30
	02/05/2018 12:29	02/05/2018 16:29	02/05/2018 20:29	03/05/2018 00:29	03/05/2018 04:29	03/05/2018 08:29	03/05/2018 12:29				
	128.8(MW)	128.8(MW)	128.8(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)			General maintenance and servicing.	

Max Farm Production (MW)	Crystal Rig II								Site Capped	Additional Information	Created On
	Expected Max Output (MW)							Estimated End			
	Start	Time 1	Time 2	Time 3	Time 4	Time 5	Time 6				
138	01/05/2018 08:00	01/05/2018 12:00	01/05/2018 16:00	01/05/2018 20:00	02/05/2018 00:00	02/05/2018 04:00	02/05/2018 08:00	01/05/2018 12:00	N		01/05/2018 08:34
138	126.5(MW)	126.5(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	30/04/2018 16:25	N	5 Turbines offline for service and statutory inspections	30/04/2018 12:26
	30/04/2018 12:25	30/04/2018 16:25	30/04/2018 20:25	01/05/2018 00:25	01/05/2018 04:25	01/05/2018 08:25	01/05/2018 12:25				
138	126.5(MW)	126.5(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	30/04/2018 13:10	N	5 turbines offline - 1 with ongoing HV issues, 4 for stat inspections/annual service and M system replacement	30/04/2018 09:12
	30/04/2018 09:10	30/04/2018 13:10	30/04/2018 17:10	30/04/2018 21:10	01/05/2018 01:10	01/05/2018 05:10	01/05/2018 09:10				
138	126.5(MW)	126.5(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	27/04/2018 14:52	N	5 turbines offline - 4 for service/maintenance work, 1 with ongoing HV issues	27/04/2018 10:55
	27/04/2018 10:52	27/04/2018 14:52	27/04/2018 18:52	27/04/2018 22:52	28/04/2018 02:52	28/04/2018 06:52	28/04/2018 10:52				
138	124.2(MW)	124.2(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	26/04/2018 13:06	N	5 turbines offline maintenance, 1 turbine faulted	26/04/2018 09:07
	26/04/2018 09:06	26/04/2018 13:06	26/04/2018 17:06	26/04/2018 21:06	27/04/2018 01:06	27/04/2018 05:06	27/04/2018 09:06				
138	124.2(MW)	126.5(MW)	126.5(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	25/04/2018 13:14	N	Maintenance x 5, faulted x1	25/04/2018 09:15
	25/04/2018 09:14	25/04/2018 13:14	25/04/2018 17:14	25/04/2018 21:14	26/04/2018 01:14	26/04/2018 05:14	26/04/2018 09:14				
138	128.8(MW)	128.8(MW)	128.8(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	24/04/2018 12:30	N	3 service 1 long term fault	24/04/2018 08:27
	24/04/2018 08:30	24/04/2018 12:30	24/04/2018 16:30	24/04/2018 20:30	25/04/2018 00:30	25/04/2018 04:30	25/04/2018 08:30				
138	126.5(MW)	126.5(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	19/04/2018 12:11	N	Service/fault	19/04/2018 08:12
	19/04/2018 08:11	19/04/2018 12:11	19/04/2018 16:11	19/04/2018 20:11	20/04/2018 00:11	20/04/2018 04:11	20/04/2018 08:11				
	124.2(MW)	124.2(MW)	138(MW)	138(MW)	138(MW)	138(MW)	138(MW)			Service	

Max Farm Production (MW)	Crystal Rig II								Site Capped	Additional Information	Created On
	Expected Max Output (MW)							Estimated End			
	Start	Time 1	Time 2	Time 3	Time 4	Time 5	Time 6				
138	18/04/2018 08:34	18/04/2018 12:34	18/04/2018 16:34	18/04/2018 20:34	19/04/2018 00:34	19/04/2018 04:34	19/04/2018 08:34	18/04/2018 16:34	N		18/04/2018 08:35
138	121.9(MW)	121.9(MW)	133.4(MW)	133.4(MW)	133.4(MW)	133.4(MW)	133.4(MW)	17/04/2018 14:05	N	Maintenance/faults	17/04/2018 10:06
	17/04/2018 10:05	17/04/2018 14:05	17/04/2018 18:05	17/04/2018 22:05	18/04/2018 02:05	18/04/2018 06:05	18/04/2018 10:05				
138	126.5(MW)	126.5(MW)	133.4(MW)	133.4(MW)	133.4(MW)	133.4(MW)	133.4(MW)	16/04/2018 13:05	N	Faults	16/04/2018 09:05
	16/04/2018 09:05	16/04/2018 13:05	16/04/2018 17:05	16/04/2018 21:05	17/04/2018 01:05	17/04/2018 05:05	17/04/2018 09:05				
138	128.8(MW)	128.8(MW)	128.8(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	13/04/2018 12:29	N	Turbine maintenance	13/04/2018 08:29
	13/04/2018 08:29	13/04/2018 12:29	13/04/2018 16:29	13/04/2018 20:29	14/04/2018 00:29	14/04/2018 04:29	14/04/2018 08:29				
138	126.5(MW)	126.5(MW)	133.4(MW)	133.4(MW)	133.4(MW)	133.4(MW)	133.4(MW)	12/04/2018 16:00	N	2 turbines remain offline, 3 in service	12/04/2018 12:19
	12/04/2018 12:00	12/04/2018 16:00	12/04/2018 20:00	13/04/2018 00:00	13/04/2018 04:00	13/04/2018 08:00	13/04/2018 12:00				
138	126.5(MW)	126.5(MW)	126.5(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	10/04/2018 13:28	N	4turbines in service, 1 turbine offline with HV issues	10/04/2018 09:29
	10/04/2018 09:28	10/04/2018 13:28	10/04/2018 17:28	10/04/2018 21:28	11/04/2018 01:28	11/04/2018 05:28	11/04/2018 09:28				
138	126.5(MW)	126.5(MW)	126.5(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	10/04/2018 13:11	N	4 turbines in service, 1 turbine offline with hv issues	10/04/2018 09:13
	10/04/2018 09:11	10/04/2018 13:11	10/04/2018 17:11	10/04/2018 21:11	11/04/2018 01:11	11/04/2018 05:11	11/04/2018 09:11				
138	126.5(MW)	126.5(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	09/04/2018 16:15	N	4 turbines in service, 1 turbine offline with ongoing hv issues	09/04/2018 12:16
	09/04/2018 12:15	09/04/2018 16:15	09/04/2018 20:15	10/04/2018 00:15	10/04/2018 04:15	10/04/2018 08:15	10/04/2018 12:15				
	124.2(MW)	124.2(MW)	124.2(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)			3 turbines in service, 1 offline with HV issues and 2 offline - service	

Max Farm Production (MW)	Crystal Rig II								Site Capped	Additional Information	Created On
	Expected Max Output (MW)							Estimated End			
	Start	Time 1	Time 2	Time 3	Time 4	Time 5	Time 6				
138	06/04/2018 08:32	06/04/2018 12:32	06/04/2018 16:32	06/04/2018 20:32	07/04/2018 00:32	07/04/2018 04:32	07/04/2018 08:32	06/04/2018 12:32	N	aware	06/04/2018 08:34
138	126.5(MW)	126.5(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	05/04/2018 16:00	N	T21 ongoing maintenance. Annual service and Stat inspections ongoing.	05/04/2018 12:28
	05/04/2018 12:00	05/04/2018 16:00	05/04/2018 20:00	06/04/2018 00:00	06/04/2018 04:00	06/04/2018 08:00	06/04/2018 12:00				
138	126.5(MW)	126.5(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	04/04/2018 16:20	N	Turbine 21 ongoing. 4 turbines general maintenance	04/04/2018 12:33
	04/04/2018 12:20	04/04/2018 16:20	04/04/2018 20:20	05/04/2018 00:20	05/04/2018 04:20	05/04/2018 08:20	05/04/2018 12:20				
138	119.6(MW)	119.6(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	03/04/2018 16:00	N	4 turbines offline for annual service. 1 turbine offline for stat inspections. 1 turbine offline for general maintenance and 2 turbines faulted.	03/04/2018 12:17
	03/04/2018 12:00	03/04/2018 16:00	03/04/2018 20:00	04/04/2018 00:00	04/04/2018 04:00	04/04/2018 08:00	04/04/2018 12:00				
138	128.8(MW)	133.4(MW)	133.4(MW)	133.4(MW)	133.4(MW)	133.4(MW)	133.4(MW)	30/03/2018 16:26	N	2 turbines in service, 2 turbines with faults	30/03/2018 12:30
	30/03/2018 12:26	30/03/2018 16:26	30/03/2018 20:26	31/03/2018 00:26	31/03/2018 04:26	31/03/2018 08:26	31/03/2018 12:26				
138	128.8(MW)	133.4(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	29/03/2018 16:33	N	2 turbines being serviced, 2 with faults.	29/03/2018 12:34
	29/03/2018 12:33	29/03/2018 16:33	29/03/2018 20:33	30/03/2018 00:33	30/03/2018 04:33	30/03/2018 08:33	30/03/2018 12:33				
138	117.3(MW)	117.3(MW)	117.3(MW)	133.4(MW)	133.4(MW)	133.4(MW)	133.4(MW)	28/03/2018 12:00	N	1 string out for HV maintenance	27/03/2018 13:02
	28/03/2018 08:00	28/03/2018 12:00	28/03/2018 16:00	28/03/2018 20:00	29/03/2018 00:00	29/03/2018 04:00	29/03/2018 08:00				
138	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	131.1(MW)	131.1(MW)	131.1(MW)	27/03/2018 00:00	N	Turbines 21, 41 and 42 - ongoing maintenance work. T4 faulted.	26/03/2018 20:14
	26/03/2018 20:00	27/03/2018 00:00	27/03/2018 04:00	27/03/2018 08:00	27/03/2018 12:00	27/03/2018 16:00	27/03/2018 20:00				
	128.8(MW)	131.1(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)			HV work @ maintenance	

Max Farm Production (MW)	Crystal Rig II								Site Capped	Additional Information	Created On
	Expected Max Output (MW)							Estimated End			
	Start	Time 1	Time 2	Time 3	Time 4	Time 5	Time 6				
138	26/03/2018 12:19	26/03/2018 16:19	26/03/2018 20:19	27/03/2018 00:19	27/03/2018 04:19	27/03/2018 08:19	27/03/2018 12:19	26/03/2018 16:19	N		26/03/2018 12:20
138	128.8(MW)	128.8(MW)	131.1(MW)	131.1(MW)	131.1(MW)	131.1(MW)	131.1(MW)	23/03/2018 16:09	N	3 turbines offline with ongoin problems. 1 turbine in service	23/03/2018 12:10
	23/03/2018 12:09	23/03/2018 16:09	23/03/2018 20:09	24/03/2018 00:09	24/03/2018 04:09	24/03/2018 08:09	24/03/2018 12:09				
138	126.5(MW)	126.5(MW)	128.8(MW)	131.1(MW)	131.1(MW)	131.1(MW)	131.1(MW)	22/03/2018 12:35	N	Currently, 4 turbines faulted, 1 being serviced.	22/03/2018 08:37
	22/03/2018 08:35	22/03/2018 12:35	22/03/2018 16:35	22/03/2018 20:35	23/03/2018 00:35	23/03/2018 04:35	23/03/2018 08:35				
138	128.8(MW)	128.8(MW)	128.8(MW)	131.1(MW)	131.1(MW)	131.1(MW)	131.1(MW)	22/03/2018 04:04	N	Faults	22/03/2018 00:05
	22/03/2018 00:04	22/03/2018 04:04	22/03/2018 08:04	22/03/2018 12:04	22/03/2018 16:04	22/03/2018 20:04	23/03/2018 00:04				
138	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	131.1(MW)	131.1(MW)	20/03/2018 00:14	N	Turbine faults	19/03/2018 20:17
	19/03/2018 20:14	20/03/2018 00:14	20/03/2018 04:14	20/03/2018 08:14	20/03/2018 12:14	20/03/2018 16:14	20/03/2018 20:14				
138	128.8(MW)	128.8(MW)	131.1(MW)	131.1(MW)	131.1(MW)	131.1(MW)	131.1(MW)	19/03/2018 08:00	N	3 turbines - Ongoing Maintenance. 1 turbine - faulted	19/03/2018 04:06
	19/03/2018 04:00	19/03/2018 08:00	19/03/2018 12:00	19/03/2018 16:00	19/03/2018 20:00	20/03/2018 00:00	20/03/2018 04:00				
138	131.1(MW)	131.1(MW)	131.1(MW)	131.1(MW)	131.1(MW)	131.1(MW)	131.1(MW)	17/03/2018 17:00	N	Turbines Offline for Maint and Repair	17/03/2018 13:23
	17/03/2018 13:00	17/03/2018 17:00	17/03/2018 21:00	18/03/2018 01:00	18/03/2018 05:00	18/03/2018 09:00	18/03/2018 13:00				
138	128.8(MW)	131.1(MW)	131.1(MW)	131.1(MW)	131.1(MW)	131.1(MW)	131.1(MW)	17/03/2018 17:00	N	Turbines offline for Maintenance and repair	17/03/2018 13:12
	17/03/2018 13:00	17/03/2018 17:00	17/03/2018 21:00	18/03/2018 01:00	18/03/2018 05:00	18/03/2018 09:00	18/03/2018 13:00				
	124.2(MW)	124.2(MW)	124.2(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)			5 x maintenance 1x faulted	

Max Farm Production (MW)	Crystal Rig II								Site Capped	Additional Information	Created On
	Expected Max Output (MW)							Estimated End			
	Start	Time 1	Time 2	Time 3	Time 4	Time 5	Time 6				
138	16/03/2018 09:54	16/03/2018 13:54	16/03/2018 17:54	16/03/2018 21:54	17/03/2018 01:54	17/03/2018 05:54	17/03/2018 09:54	16/03/2018 13:54	N		16/03/2018 09:55
138	128.8(MW)	128.8(MW)	133.4(MW)	133.4(MW)	133.4(MW)	133.4(MW)	133.4(MW)	14/03/2018 12:53	N	2 turbines off with faults - predicted to last for next 24 hours minimum. 2 turbines being serviced.	14/03/2018 08:55
	14/03/2018 08:53	14/03/2018 12:53	14/03/2018 16:53	14/03/2018 20:53	15/03/2018 00:53	15/03/2018 04:53	15/03/2018 08:53				
138	128.8(MW)	133.4(MW)	133.4(MW)	133.4(MW)	133.4(MW)	133.4(MW)	133.4(MW)	13/03/2018 16:15	N	4 turbines offline with faults	13/03/2018 12:17
	13/03/2018 12:15	13/03/2018 16:15	13/03/2018 20:15	14/03/2018 00:15	14/03/2018 04:15	14/03/2018 08:15	14/03/2018 12:15				
138	115(MW)	115(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	12/03/2018 16:32	N	Turbines offline x 10 HV works	12/03/2018 12:34
	12/03/2018 12:32	12/03/2018 16:32	12/03/2018 20:32	13/03/2018 00:32	13/03/2018 04:32	13/03/2018 08:32	13/03/2018 12:32				
138	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	04/03/2018 22:00	N	4 Turbines off with faults	04/03/2018 18:43
	04/03/2018 18:00	04/03/2018 22:00	05/03/2018 02:00	05/03/2018 06:00	05/03/2018 10:00	05/03/2018 14:00	05/03/2018 18:00				
138	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	03/03/2018 20:21	N	4 turbines offline with faults.	03/03/2018 16:22
	03/03/2018 16:21	03/03/2018 20:21	04/03/2018 00:21	04/03/2018 04:21	04/03/2018 08:21	04/03/2018 12:21	04/03/2018 16:21				
138	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	02/03/2018 20:52	N	4 Turbines offline with faults (T12, 21, 43 and 46)	02/03/2018 16:56
	02/03/2018 16:52	02/03/2018 20:52	03/03/2018 00:52	03/03/2018 04:52	03/03/2018 08:52	03/03/2018 12:52	03/03/2018 16:52				
138	126.5(MW)	128.8(MW)	133.4(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	02/03/2018 12:18	N	4 x offline weather related 1 x offline faulted	02/03/2018 08:23
	02/03/2018 08:18	02/03/2018 12:18	02/03/2018 16:18	02/03/2018 20:18	03/03/2018 00:18	03/03/2018 04:18	03/03/2018 08:18				
	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	135.7(MW)	135.7(MW)			4 turbines offline with faults	

Max Farm Production (MW)	Crystal Rig II								Site Capped	Additional Information	Created On
	Expected Max Output (MW)							Estimated End			
	Start	Time 1	Time 2	Time 3	Time 4	Time 5	Time 6				
138	01/03/2018 20:18	02/03/2018 00:18	02/03/2018 04:18	02/03/2018 08:18	02/03/2018 12:18	02/03/2018 16:18	02/03/2018 20:18	02/03/2018 00:18	N		01/03/2018 20:18
138	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	01/03/2018 12:00	N	4 turbines offline with faults.	01/03/2018 09:13
	01/03/2018 08:00	01/03/2018 12:00	01/03/2018 16:00	01/03/2018 20:00	02/03/2018 00:00	02/03/2018 04:00	02/03/2018 08:00				
138	128.8(MW)	128.8(MW)	128.8(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	28/02/2018 12:16	N	3 faults and 1 offline with HV issues	28/02/2018 08:18
	28/02/2018 08:16	28/02/2018 12:16	28/02/2018 16:16	28/02/2018 20:16	01/03/2018 00:16	01/03/2018 04:16	01/03/2018 08:16				
138	128.8(MW)	128.8(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	26/02/2018 16:00	N	3 turbines being serviced. 1 turbine offline (T21)	26/02/2018 12:14
	26/02/2018 12:00	26/02/2018 16:00	26/02/2018 20:00	27/02/2018 00:00	27/02/2018 04:00	27/02/2018 08:00	27/02/2018 12:00				
138	128.8(MW)	128.8(MW)	138(MW)	138(MW)	138(MW)	138(MW)	138(MW)	01/02/2018 20:13	N	4 turbines in annual service	01/02/2018 12:15
	01/02/2018 12:13	01/02/2018 16:13	01/02/2018 20:13	02/02/2018 00:13	02/02/2018 04:13	02/02/2018 08:13	02/02/2018 12:13				
138	128.8(MW)	128.8(MW)	133.4(MW)	133.4(MW)	133.4(MW)	133.4(MW)	133.4(MW)	28/01/2018 12:00	N	T27 and T56 require maintenance. T17 and 49 ongoing.	28/01/2018 08:11
	28/01/2018 08:00	28/01/2018 12:00	28/01/2018 16:00	28/01/2018 20:00	29/01/2018 00:00	29/01/2018 04:00	29/01/2018 08:00				
138	128.8(MW)	128.8(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	23/01/2018 16:42	N	3 x servicing and 1 x ongoing fault	23/01/2018 12:48
	23/01/2018 12:42	23/01/2018 16:42	23/01/2018 20:42	24/01/2018 00:42	24/01/2018 04:42	24/01/2018 08:42	24/01/2018 12:42				
138	128.8(MW)	128.8(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	09/01/2018 12:00	N	T49 work ongoing. T9 Service. T36 and T33 general maintenance.	09/01/2018 08:24
	09/01/2018 08:00	09/01/2018 12:00	09/01/2018 16:00	09/01/2018 20:00	10/01/2018 00:00	10/01/2018 04:00	10/01/2018 08:00				
	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	135.7(MW)	135.7(MW)	135.7(MW)			T49 IMS shaft work ongoing. T33, T43 and T59 requiring general	

Max Farm Production (MW)	Crystal Rig II								Site Capped	Additional Information	Created On
	Expected Max Output (MW)							Estimated End			
	Start	Time 1	Time 2	Time 3	Time 4	Time 5	Time 6				
138	03/01/2018 04:00	03/01/2018 08:00	03/01/2018 12:00	03/01/2018 16:00	03/01/2018 20:00	04/01/2018 00:00	04/01/2018 04:00	03/01/2018 08:00	N	maintenance	03/01/2018 04:10
138	128.8(MW)	128.8(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	21/12/2017 16:00	N	General maintenance work being carried out. T49 IMS shaft replacement.	21/12/2017 12:37
	21/12/2017 12:00	21/12/2017 16:00	21/12/2017 20:00	22/12/2017 00:00	22/12/2017 04:00	22/12/2017 08:00	22/12/2017 12:00				
138	126.5(MW)	126.5(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	05/12/2017 12:16	N	Fault works.	05/12/2017 08:17
	05/12/2017 08:16	05/12/2017 12:16	05/12/2017 16:16	05/12/2017 20:16	06/12/2017 00:16	06/12/2017 04:16	06/12/2017 08:16				
138	128.8(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	28/11/2017 16:00	N	Turbine maintenance ongoing.	28/11/2017 12:23
	28/11/2017 12:00	28/11/2017 16:00	28/11/2017 20:00	29/11/2017 00:00	29/11/2017 04:00	29/11/2017 08:00	29/11/2017 12:00				
138	128.8(MW)	128.8(MW)	138(MW)	138(MW)	138(MW)	138(MW)	138(MW)	27/11/2017 16:30	N	servicing ongoing.	27/11/2017 08:42
	27/11/2017 08:30	27/11/2017 12:30	27/11/2017 16:30	27/11/2017 20:30	28/11/2017 00:30	28/11/2017 04:30	28/11/2017 08:30				
138	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	138(MW)	138(MW)	01/11/2017 17:21	N	offline for routine maintenance.	31/10/2017 21:33
	31/10/2017 21:21	01/11/2017 01:21	01/11/2017 05:21	01/11/2017 09:21	01/11/2017 13:21	01/11/2017 17:21	01/11/2017 21:21				
138	126.5(MW)	138(MW)	138(MW)	138(MW)	138(MW)	138(MW)	138(MW)	10/10/2017 17:00	N	Techs working to reset turbines after Grid trip test.	10/10/2017 13:02
	10/10/2017 13:00	10/10/2017 17:00	10/10/2017 21:00	11/10/2017 01:00	11/10/2017 05:00	11/10/2017 09:00	11/10/2017 13:00				
138	128.8(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	08/09/2017 16:39	N	3 turbine servicing - 1 off-line long-term	08/09/2017 12:41
	08/09/2017 12:39	08/09/2017 16:39	08/09/2017 20:39	09/09/2017 00:39	09/09/2017 04:39	09/09/2017 08:39	09/09/2017 12:39				
	135.7(MW)	-	-	-	-	-	-			Turbine 16 will remain offline for the blade tip extension works.	

Max Farm Production (MW)	Crystal Rig II							Site Capped	Additional Information	Created On	
	Expected Max Output (MW)										Estimated End
	Start	Time 1	Time 2	Time 3	Time 4	Time 5	Time 6				
138	22/08/2017 17:45	-	-	-	-	-	-	12/09/2017 17:00	N		22/08/2017 17:46
138	128.8(MW)	128.8(MW)	138(MW)	138(MW)	138(MW)	138(MW)	138(MW)	16/08/2017 20:21	N	Turbines being serviced or in error	16/08/2017 12:25
	16/08/2017 12:21	16/08/2017 16:21	16/08/2017 20:21	17/08/2017 00:21	17/08/2017 04:21	17/08/2017 08:21	17/08/2017 12:21				
138	133.4(MW)	133.4(MW)	133.4(MW)	133.4(MW)	133.4(MW)	133.4(MW)	133.4(MW)	10/08/2017 20:11	N	T7 awaiting Blade repairs . T16 Blade tip extension works ongoing	10/08/2017 16:16
	10/08/2017 16:11	10/08/2017 20:11	11/08/2017 00:11	11/08/2017 04:11	11/08/2017 08:11	11/08/2017 12:11	11/08/2017 16:11				
138	126.5(MW)	126.5(MW)	126.5(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	10/08/2017 16:32	N	4 turbines in service, T7 offline awaiting blade repairs	10/08/2017 12:34
	10/08/2017 12:32	10/08/2017 16:32	10/08/2017 20:32	11/08/2017 00:32	11/08/2017 04:32	11/08/2017 08:32	11/08/2017 12:32				
138	128.8(MW)	128.8(MW)	133.4(MW)	133.4(MW)	133.4(MW)	133.4(MW)	133.4(MW)	10/08/2017 08:00	N	4 turbines offline requiring repairs or ongoing maintenance.	10/08/2017 04:03
	10/08/2017 04:00	10/08/2017 08:00	10/08/2017 12:00	10/08/2017 16:00	10/08/2017 20:00	11/08/2017 00:00	11/08/2017 04:00				
138	128.8(MW)	128.8(MW)	138(MW)	138(MW)	138(MW)	138(MW)	138(MW)	28/07/2017 20:17	N	Technicians working on the turbines.	28/07/2017 12:17
	28/07/2017 12:17	28/07/2017 16:17	28/07/2017 20:17	29/07/2017 00:17	29/07/2017 04:17	29/07/2017 08:17	29/07/2017 12:17				
138	128.8(MW)	128.8(MW)	138(MW)	138(MW)	138(MW)	138(MW)	138(MW)	28/07/2017 12:10	N	Turbine faults	28/07/2017 04:11
	28/07/2017 04:10	28/07/2017 08:10	28/07/2017 12:10	28/07/2017 16:10	28/07/2017 20:10	29/07/2017 00:10	29/07/2017 04:10				
138	108.1(MW)	108.1(MW)	138(MW)	138(MW)	138(MW)	138(MW)	138(MW)	27/07/2017 20:09	N	11 turbines that are offline due to a discharge investigation issue. 2 tyrbines off for maintenance and 6 tyrbins that are producing but we have no control of.	27/07/2017 12:11
	27/07/2017 12:09	27/07/2017 16:09	27/07/2017 20:09	28/07/2017 00:09	28/07/2017 04:09	28/07/2017 08:09	28/07/2017 12:09				
	98.9(MW)	98.9(MW)	98.9(MW)	98.9(MW)	98.9(MW)	98.9(MW)	138(MW)			11 turbines are offline due to partial discharge investigation. No	

Max Farm Production (MW)	Crystal Rig II								Site Capped	Additional Information	Created On
	Expected Max Output (MW)							Estimated End			
	Start	Time 1	Time 2	Time 3	Time 4	Time 5	Time 6				
138	26/07/2017 16:49	26/07/2017 20:49	27/07/2017 00:49	27/07/2017 04:49	27/07/2017 08:49	27/07/2017 12:49	27/07/2017 16:49	27/07/2017 16:49	N	communication to 6 turbines therefore no ability to curtail, however these 6 turbines are producing.	26/07/2017 16:53
138	98.9(MW)	98.9(MW)	98.9(MW)	98.9(MW)	98.9(MW)	98.9(MW)	138(MW)	27/07/2017 16:16	N	11 turbines offline due to a partial discharge investigation. No communication to 6 turbines therefore no ability to curtail, however these 6 turbines are producing.	26/07/2017 16:24
	26/07/2017 16:16	26/07/2017 20:16	27/07/2017 00:16	27/07/2017 04:16	27/07/2017 08:16	27/07/2017 12:16	27/07/2017 16:16				
138	126.5(MW)	126.5(MW)	126.5(MW)	126.5(MW)	126.5(MW)	126.5(MW)	126.5(MW)	26/07/2017 12:17	N	.	26/07/2017 08:17
	26/07/2017 08:17	26/07/2017 12:17	26/07/2017 16:17	26/07/2017 20:17	27/07/2017 00:17	27/07/2017 04:17	27/07/2017 08:17				
138	98.9(MW)	98.9(MW)	98.9(MW)	98.9(MW)	98.9(MW)	98.9(MW)	138(MW)	26/07/2017 20:30	N	11 turbines are offline due to partial discharge investigation. No communication to 6 turbines therefore no ability to curtail, however these 6 turbines are producing.	25/07/2017 20:42
	25/07/2017 20:30	26/07/2017 00:30	26/07/2017 04:30	26/07/2017 08:30	26/07/2017 12:30	26/07/2017 16:30	26/07/2017 20:30				
138	126.5(MW)	126.5(MW)	126.5(MW)	126.5(MW)	126.5(MW)	126.5(MW)	126.5(MW)	25/07/2017 21:35	N	.	25/07/2017 17:36
	25/07/2017 17:35	25/07/2017 21:35	26/07/2017 01:35	26/07/2017 05:35	26/07/2017 09:35	26/07/2017 13:35	26/07/2017 17:35				
138	98.9(MW)	126.5(MW)	126.5(MW)	126.5(MW)	126.5(MW)	126.5(MW)	126.5(MW)	25/07/2017 20:14	N	.	25/07/2017 16:16
	25/07/2017 16:14	25/07/2017 20:14	26/07/2017 00:14	26/07/2017 04:14	26/07/2017 08:14	26/07/2017 12:14	26/07/2017 16:14				
138	112.7(MW)	112.7(MW)	133.4(MW)	133.4(MW)	133.4(MW)	133.4(MW)	133.4(MW)	25/07/2017 16:26	N	.	25/07/2017 12:27
	25/07/2017 12:26	25/07/2017 16:26	25/07/2017 20:26	26/07/2017 00:26	26/07/2017 04:26	26/07/2017 08:26	26/07/2017 12:26				
138	128.8(MW)	128.8(MW)	133.4(MW)	133.4(MW)	133.4(MW)	133.4(MW)	133.4(MW)	25/07/2017 12:29	N	.	25/07/2017 08:36
	25/07/2017 08:29	25/07/2017 12:29	25/07/2017 16:29	25/07/2017 20:29	26/07/2017 00:29	26/07/2017 04:29	26/07/2017 08:29				
	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	138(MW)	138(MW)			4 turbines offline with communication issues. Techs are aware.	

Max Farm Production (MW)	Crystal Rig II								Site Capped	Additional Information	Created On
	Expected Max Output (MW)							Estimated End			
	Start	Time 1	Time 2	Time 3	Time 4	Time 5	Time 6				
138	24/07/2017 20:00	25/07/2017 00:00	25/07/2017 04:00	25/07/2017 08:00	25/07/2017 12:00	25/07/2017 16:00	25/07/2017 20:00	25/07/2017 16:00	N		24/07/2017 20:11
138	128.8(MW)	133.4(MW)	133.4(MW)	133.4(MW)	133.4(MW)	133.4(MW)	133.4(MW)	24/07/2017 20:18	N		24/07/2017 16:19
	24/07/2017 16:18	24/07/2017 20:18	25/07/2017 00:18	25/07/2017 04:18	25/07/2017 08:18	25/07/2017 12:18	25/07/2017 16:18				
138	115(MW)	138(MW)	138(MW)	138(MW)	138(MW)	138(MW)	138(MW)	18/07/2017 20:18	N	9 turbines off for hv maintenance and 1 turbine off for blade tip extension work	18/07/2017 16:21
	18/07/2017 16:18	18/07/2017 20:18	19/07/2017 00:18	19/07/2017 04:18	19/07/2017 08:18	19/07/2017 12:18	19/07/2017 16:18				
138	112.7(MW)	117.3(MW)	138(MW)	138(MW)	138(MW)	138(MW)	138(MW)	18/07/2017 20:18	N	9 x HV repairs, 1 x Service, 1 x Blade tip Extension works.	18/07/2017 12:22
	18/07/2017 12:18	18/07/2017 16:18	18/07/2017 20:18	19/07/2017 00:18	19/07/2017 04:18	19/07/2017 08:18	19/07/2017 12:18				
138	124.2(MW)	124.2(MW)	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	18/07/2017 12:23	N	4 x WTG's with ongoing substation investigation. 2 x WTG being serviced.	18/07/2017 08:27
	18/07/2017 08:23	18/07/2017 12:23	18/07/2017 16:23	18/07/2017 20:23	19/07/2017 00:23	19/07/2017 04:23	19/07/2017 08:23				
138	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	138(MW)	138(MW)	138(MW)	18/07/2017 12:20	N	Awaiting to find out availability of PSUK to carry out switchgear repair	17/07/2017 20:29
	17/07/2017 20:20	18/07/2017 00:20	18/07/2017 04:20	18/07/2017 08:20	18/07/2017 12:20	18/07/2017 16:20	18/07/2017 20:20				
138	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	17/07/2017 20:09	N	Ongoing Switchgear Investigation	17/07/2017 16:10
	17/07/2017 16:09	17/07/2017 20:09	18/07/2017 00:09	18/07/2017 04:09	18/07/2017 08:09	18/07/2017 12:09	18/07/2017 16:09				
138	124.2(MW)	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	17/07/2017 16:16	N	2 WTG's in Service, 4 WTG's with ongoing switchgear investigation.	17/07/2017 12:18
	17/07/2017 12:16	17/07/2017 16:16	17/07/2017 20:16	18/07/2017 00:16	18/07/2017 04:16	18/07/2017 08:16	18/07/2017 12:16				
	126.5(MW)	126.5(MW)	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)			Switchgear investigation on 4 WTG's. Service on 1 WTG.	

Max Farm Production (MW)	Crystal Rig II								Site Capped	Additional Information	Created On
	Expected Max Output (MW)							Estimated End			
	Start	Time 1	Time 2	Time 3	Time 4	Time 5	Time 6				
138	17/07/2017 08:48	17/07/2017 12:48	17/07/2017 16:48	17/07/2017 20:48	18/07/2017 00:48	18/07/2017 04:48	18/07/2017 08:48	17/07/2017 12:48	N		17/07/2017 08:50
138	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	16/07/2017 12:00	N	Awaiting to find out availability of PSUK to carry out switchgear repairs	16/07/2017 08:17
	16/07/2017 08:00	16/07/2017 12:00	16/07/2017 16:00	16/07/2017 20:00	17/07/2017 00:00	17/07/2017 04:00	17/07/2017 08:00				
138	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	15/07/2017 12:00	N	Awaiting to find out availability of PSUK to carry out switchgear repairs	15/07/2017 08:01
	15/07/2017 08:00	15/07/2017 12:00	15/07/2017 16:00	15/07/2017 20:00	16/07/2017 00:00	16/07/2017 04:00	16/07/2017 08:00				
138	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	14/07/2017 20:06	N	4 turbines off, awaiting to find out availability of PSUK to carry out switchgear repairs	14/07/2017 16:08
	14/07/2017 16:06	14/07/2017 20:06	15/07/2017 00:06	15/07/2017 04:06	15/07/2017 08:06	15/07/2017 12:06	15/07/2017 16:06				
138	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	14/07/2017 12:00	N	4 turbines off due to TS08 discharge	14/07/2017 08:42
	14/07/2017 08:00	14/07/2017 12:00	14/07/2017 16:00	14/07/2017 20:00	15/07/2017 00:00	15/07/2017 04:00	15/07/2017 08:00				
138	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	13/07/2017 20:14	N	Awaiting to find out availability of PSUK to carry out switchgear repairs	13/07/2017 16:15
	13/07/2017 16:14	13/07/2017 20:14	14/07/2017 00:14	14/07/2017 04:14	14/07/2017 08:14	14/07/2017 12:14	14/07/2017 16:14				
138	121.9(MW)	121.9(MW)	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	13/07/2017 12:30	N	Service/Awaiting repair	13/07/2017 08:44
	13/07/2017 08:30	13/07/2017 12:30	13/07/2017 16:30	13/07/2017 20:30	14/07/2017 00:30	14/07/2017 04:30	14/07/2017 08:30				
138	124.2(MW)	124.2(MW)	128.8(MW)	128.8(MW)	138(MW)	138(MW)	138(MW)	13/07/2017 20:00	N	4 turbines remain off due to partial discharge at TS08, 2 x WTG'S Offline in fault condition	13/07/2017 04:14
	13/07/2017 04:00	13/07/2017 08:00	13/07/2017 12:00	13/07/2017 16:00	13/07/2017 20:00	14/07/2017 00:00	14/07/2017 04:00				
	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)	128.8(MW)			4 turbines remain off due to partial discharge at TS08	

Max Farm Production (MW)	Crystal Rig II								Site Capped	Additional Information	Created On
	Expected Max Output (MW)							Estimated End			
	Start	Time 1	Time 2	Time 3	Time 4	Time 5	Time 6				
138	12/07/2017 18:00	12/07/2017 22:00	13/07/2017 02:00	13/07/2017 06:00	13/07/2017 10:00	13/07/2017 14:00	13/07/2017 18:00	12/07/2017 22:00	N		12/07/2017 17:40
138	108.1(MW)	108.1(MW)	133.4(MW)	138(MW)	138(MW)	138(MW)	138(MW)	20/06/2017 21:01	N	Software updates and service work	20/06/2017 09:02
	20/06/2017 09:01	20/06/2017 13:01	20/06/2017 17:01	20/06/2017 21:01	21/06/2017 01:01	21/06/2017 05:01	21/06/2017 09:01				
138	110.4(MW)	138(MW)	138(MW)	138(MW)	138(MW)	138(MW)	138(MW)	19/06/2017 20:49	N	12 turbines offline for software updates	19/06/2017 16:50
	19/06/2017 16:49	19/06/2017 20:49	20/06/2017 00:49	20/06/2017 04:49	20/06/2017 08:49	20/06/2017 12:49	20/06/2017 16:49				
138	117.3(MW)	138(MW)	138(MW)	138(MW)	138(MW)	138(MW)	138(MW)	19/06/2017 17:00	N	Remote updates in progress	19/06/2017 13:02
	19/06/2017 13:00	19/06/2017 17:00	19/06/2017 21:00	20/06/2017 01:00	20/06/2017 05:00	20/06/2017 09:00	20/06/2017 13:00				
138	128.8(MW)	128.8(MW)	138(MW)	138(MW)	138(MW)	138(MW)	138(MW)	14/06/2017 20:48	N	4 turbines off for stat inspections and annual maintenance	14/06/2017 12:53
	14/06/2017 12:48	14/06/2017 16:48	14/06/2017 20:48	15/06/2017 00:48	15/06/2017 04:48	15/06/2017 08:48	15/06/2017 12:48				
138	128.8(MW)	128.8(MW)	138(MW)	138(MW)	138(MW)	138(MW)	138(MW)	14/06/2017 20:38	N	4 turbines off for stat inspections and annual maintenance	14/06/2017 12:39
	14/06/2017 12:38	14/06/2017 16:38	14/06/2017 20:38	15/06/2017 00:38	15/06/2017 04:38	15/06/2017 08:38	15/06/2017 12:38				
138	128.8(MW)	128.8(MW)	128.8(MW)	138(MW)	138(MW)	138(MW)	138(MW)	13/06/2017 20:00	N	All 4 turbines off for Maintenance.	13/06/2017 08:30
	13/06/2017 08:00	13/06/2017 12:00	13/06/2017 16:00	13/06/2017 20:00	14/06/2017 00:00	14/06/2017 04:00	14/06/2017 08:00				
138	126.5(MW)	126.5(MW)	138(MW)	138(MW)	138(MW)	138(MW)	138(MW)	08/06/2017 20:10	N	Turbine maintenance x 5	08/06/2017 12:11
	08/06/2017 12:10	08/06/2017 16:10	08/06/2017 20:10	09/06/2017 00:10	09/06/2017 04:10	09/06/2017 08:10	09/06/2017 12:10				
	128.8(MW)	128.8(MW)	138(MW)	138(MW)	138(MW)	138(MW)	138(MW)			Technicians are currently carrying out maintenance on turbines 40,	

Max Farm Production (MW)	Crystal Rig II								Site Capped	Additional Information	Created On
	Expected Max Output (MW)							Estimated End			
	Start	Time 1	Time 2	Time 3	Time 4	Time 5	Time 6				
138	06/06/2017 12:00	06/06/2017 16:00	06/06/2017 20:00	07/06/2017 00:00	07/06/2017 04:00	07/06/2017 08:00	07/06/2017 12:00	06/06/2017 20:00	N	41, 42 and 44.	06/06/2017 12:12
138	128.8(MW)	128.8(MW)	138(MW)	138(MW)	138(MW)	138(MW)	138(MW)	05/06/2017 20:20	N	Technicians currently in possession of Turbines 16, 41, 51 and 60. Ongoing maintenance work.	05/06/2017 12:31
	05/06/2017 12:20	05/06/2017 16:20	05/06/2017 20:20	06/06/2017 00:20	06/06/2017 04:20	06/06/2017 08:20	06/06/2017 12:20				
138	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	138(MW)	138(MW)	26/05/2017 16:41	N	1 Turbine requiring manual reset	25/05/2017 20:44
	25/05/2017 20:41	26/05/2017 00:41	26/05/2017 04:41	26/05/2017 08:41	26/05/2017 12:41	26/05/2017 16:41	26/05/2017 20:41				
138	128.8(MW)	138(MW)	138(MW)	138(MW)	138(MW)	138(MW)	138(MW)	25/05/2017 16:00	N	Annual service of turbines.	25/05/2017 12:19
	25/05/2017 12:00	25/05/2017 16:00	25/05/2017 20:00	26/05/2017 00:00	26/05/2017 04:00	26/05/2017 08:00	26/05/2017 12:00				
138	128.8(MW)	128.8(MW)	138(MW)	138(MW)	138(MW)	138(MW)	138(MW)	04/05/2017 20:00	N	Noise monitoring	04/05/2017 12:32
	04/05/2017 12:00	04/05/2017 16:00	04/05/2017 20:00	05/05/2017 00:00	05/05/2017 04:00	05/05/2017 08:00	05/05/2017 12:00				
138	128.8(MW)	138(MW)	138(MW)	138(MW)	138(MW)	138(MW)	138(MW)	28/04/2017 16:12	N	WTG's in service	28/04/2017 12:12
	28/04/2017 12:12	28/04/2017 16:12	28/04/2017 20:12	29/04/2017 00:12	29/04/2017 04:12	29/04/2017 08:12	29/04/2017 12:12				
138	128.8(MW)	128.8(MW)	138(MW)	138(MW)	138(MW)	138(MW)	138(MW)	18/04/2017 21:22	N	Maintenance x4	18/04/2017 13:24
	18/04/2017 13:22	18/04/2017 17:22	18/04/2017 21:22	19/04/2017 01:22	19/04/2017 05:22	19/04/2017 09:22	19/04/2017 13:22				
138	128.8(MW)	128.8(MW)	128.8(MW)	138(MW)	138(MW)	138(MW)	138(MW)	18/04/2017 00:18	N	4 turbines offline for Service works.	17/04/2017 12:20
	17/04/2017 12:18	17/04/2017 16:18	17/04/2017 20:18	18/04/2017 00:18	18/04/2017 04:18	18/04/2017 08:18	18/04/2017 12:18				
	128.8(MW)	128.8(MW)	138(MW)	138(MW)	138(MW)	138(MW)	138(MW)			Servicing and maintenance	

Max Farm Production (MW)	Crystal Rig II								Site Capped	Additional Information	Created On
	Expected Max Output (MW)							Estimated End			
	Start	Time 1	Time 2	Time 3	Time 4	Time 5	Time 6				
138	04/04/2017 12:44	04/04/2017 16:44	04/04/2017 20:44	05/04/2017 00:44	05/04/2017 04:44	05/04/2017 08:44	05/04/2017 12:44	04/04/2017 20:44	N		04/04/2017 12:45
138	128.8(MW)	128.8(MW)	138(MW)	138(MW)	138(MW)	138(MW)	138(MW)	04/04/2017 20:28	N	4 turbines off for service	04/04/2017 12:31
	04/04/2017 12:28	04/04/2017 16:28	04/04/2017 20:28	05/04/2017 00:28	05/04/2017 04:28	05/04/2017 08:28	05/04/2017 12:28				
138	128.8(MW)	128.8(MW)	128.8(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	01/03/2017 12:36	N	WTG maintenance	01/03/2017 08:37
	01/03/2017 08:36	01/03/2017 12:36	01/03/2017 16:36	01/03/2017 20:36	02/03/2017 00:36	02/03/2017 04:36	02/03/2017 08:36				
138	108.1(MW)	108.1(MW)	108.1(MW)	108.1(MW)	108.1(MW)	108.1(MW)	135.7(MW)	23/02/2017 12:54	N	12 turbines stopped due to ice detection	23/02/2017 08:56
	23/02/2017 08:54	23/02/2017 12:54	23/02/2017 16:54	23/02/2017 20:54	24/02/2017 00:54	24/02/2017 04:54	24/02/2017 08:54				
104	104(MW)	-	-	-	-	-	-	15/02/2017 15:00	Y	Re-configure 132/33kV Substation for single-Grid Transformer operation : .	11/02/2017 09:02
	14/02/2017 10:30	-	-	-	-	-	-				
138	0(MW)	138(MW)	138(MW)	138(MW)	138(MW)	138(MW)	138(MW)	15/02/2017 19:00	N	Return 132/33kV Substation to normal running arrangements (GT1B shall be switched back in).	11/02/2017 08:59
	15/02/2017 15:00	15/02/2017 19:00	15/02/2017 23:00	16/02/2017 03:00	16/02/2017 07:00	16/02/2017 11:00	16/02/2017 15:00				
138	0(MW)	138(MW)	138(MW)	138(MW)	138(MW)	138(MW)	138(MW)	14/02/2017 12:30	N	Switching time outage to Re-configure 132/33kV Substation for single-Grid Transformer operation (GT1B shall be switched out) for investigation of AVC fault.	11/02/2017 08:56
	14/02/2017 08:30	14/02/2017 12:30	14/02/2017 16:30	14/02/2017 20:30	15/02/2017 00:30	15/02/2017 04:30	15/02/2017 08:30				
138	128.8(MW)	128.8(MW)	128.8(MW)	138(MW)	138(MW)	138(MW)	138(MW)	11/02/2017 20:00	N	4 x WTG'S in fault condition	11/02/2017 08:23
	11/02/2017 08:00	11/02/2017 12:00	11/02/2017 16:00	11/02/2017 20:00	12/02/2017 00:00	12/02/2017 04:00	12/02/2017 08:00				
	128.8(MW)	128.8(MW)	138(MW)	138(MW)	138(MW)	138(MW)	138(MW)			4 WTG's in fault condition	

Max Farm Production (MW)	Crystal Rig II								Site Capped	Additional Information	Created On
	Expected Max Output (MW)							Estimated End			
	Start	Time 1	Time 2	Time 3	Time 4	Time 5	Time 6				
138	11/02/2017 08:00	11/02/2017 12:00	11/02/2017 16:00	11/02/2017 20:00	12/02/2017 00:00	12/02/2017 04:00	12/02/2017 08:00	11/02/2017 16:00	N		11/02/2017 08:09
138	128.8(MW)	128.8(MW)	138(MW)	138(MW)	138(MW)	138(MW)	138(MW)	11/02/2017 08:23	N	Faulted WTG's	11/02/2017 00:24
	11/02/2017 00:23	11/02/2017 04:23	11/02/2017 08:23	11/02/2017 12:23	11/02/2017 16:23	11/02/2017 20:23	12/02/2017 00:23				
138	85.1(MW)	85.1(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	16/11/2016 20:00	N	22 turbines off with fault under investigation. 1 turbine offline for blade extension.	16/11/2016 16:24
	16/11/2016 16:00	16/11/2016 20:00	17/11/2016 00:00	17/11/2016 04:00	17/11/2016 08:00	17/11/2016 12:00	17/11/2016 16:00				
0	0(MW)	-	-	-	-	-	-	09/11/2016 19:00	Y	SPT Outage SP140326 and SP140327 : SPT Outage SP140326 and SP140327. Site outage restriction removed, work completed ahead of original RTS.	09/11/2016 19:11
	08/11/2016 08:30	-	-	-	-	-	-				
138	0(MW)	-	-	-	-	-	-	10/11/2016 16:30 09/11/2016 19:00	N	SPT Outage SP140326 and SP140327	07/11/2016 15:24
	08/11/2016 08:30	-	-	-	-	-	-				
138	126.5(MW)	126.5(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	03/11/2016 16:35	N	4 x Service and inspection, 1 x fault investigation	03/11/2016 12:37
	03/11/2016 12:35	03/11/2016 16:35	03/11/2016 20:35	04/11/2016 00:35	04/11/2016 04:35	04/11/2016 08:35	04/11/2016 12:35				
138	128.8(MW)	128.8(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	02/11/2016 16:00	N	3 turbines offline for service and inspection. 1 turbine remains offline for blade works.	02/11/2016 12:04
	02/11/2016 12:00	02/11/2016 16:00	02/11/2016 20:00	03/11/2016 00:00	03/11/2016 04:00	03/11/2016 08:00	03/11/2016 12:00				

Max Farm Production (MW)	Crystal Rig II							Estimated End	Site Capped	Additional Information	Created On
	Expected Max Output (MW)										
	Start	Time 1	Time 2	Time 3	Time 4	Time 5	Time 6				
138	126.5(MW)	126.5(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	01/11/2016 16:53	N	4x Service and 1 fault repair	01/11/2016 12:55
	01/11/2016 12:53	01/11/2016 16:53	01/11/2016 20:53	02/11/2016 00:53	02/11/2016 04:53	02/11/2016 08:53	02/11/2016 12:53				
138	0(MW)	-	-	-	-	-	-	08/11/2016 17:00	N	DNO Outage Cancelled	28/10/2016 15:54
	06/11/2016 08:00	-	-	-	-	-	-	Cancelled			
138	128.8(MW)	128.8(MW)	138(MW)	138(MW)	138(MW)	138(MW)	138(MW)	19/10/2016 20:45	N	all 4 turbines off for service works	19/10/2016 12:47
	19/10/2016 12:45	19/10/2016 16:45	19/10/2016 20:45	20/10/2016 00:45	20/10/2016 04:45	20/10/2016 08:45	20/10/2016 12:45				
138	71.3(MW)	71.3(MW)	138(MW)	138(MW)	138(MW)	138(MW)	138(MW)	16/09/2016 08:01	N	On going HV works.	16/09/2016 00:34
	16/09/2016 00:01	16/09/2016 04:01	16/09/2016 08:01	16/09/2016 12:01	16/09/2016 16:01	16/09/2016 20:01	17/09/2016 00:01				
138	71.3(MW)	71.3(MW)	71.3(MW)	71.3(MW)	138(MW)	138(MW)	138(MW)	15/09/2016 23:00	N	In support of CR3 works (the connection of the CR3 HV circuit to the existing CR2 33kV Switch Board), there will be an outage at CR2 on Thursday 15 Sep 2016, affecting String 1 (9 WTG), String 3 (9 WTG) and String 5 (11 WTG). This a total of 29 WTG (66.7MW).	14/09/2016 15:06
	15/09/2016 07:00	15/09/2016 11:00	15/09/2016 15:00	15/09/2016 19:00	15/09/2016 23:00	16/09/2016 03:00	16/09/2016 07:00				
138	124.2(MW)	124.2(MW)	138(MW)	138(MW)	138(MW)	138(MW)	138(MW)	06/09/2016 20:10	N	6 turbines offline for service works.	06/09/2016 12:10
	06/09/2016 12:10	06/09/2016 16:10	06/09/2016 20:10	07/09/2016 00:10	07/09/2016 04:10	07/09/2016 08:10	07/09/2016 12:10				
138	124.2(MW)	138(MW)	138(MW)	138(MW)	138(MW)	138(MW)	138(MW)	31/08/2016 16:20	N	2 turbines off for maintenance and 4 offline for noise monitoring on Turbine 57.	31/08/2016 12:21
	31/08/2016 12:20	31/08/2016 16:20	31/08/2016 20:20	01/09/2016 00:20	01/09/2016 04:20	01/09/2016 08:20	01/09/2016 12:20				
138	124.2(MW)	124.2(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	135.7(MW)	25/08/2016 16:31	N	Turbine maintenance	25/08/2016 12:32
	25/08/2016 12:31	25/08/2016 16:31	25/08/2016 20:31	26/08/2016 00:31	26/08/2016 04:31	26/08/2016 08:31	26/08/2016 12:31				
	128.8(MW)	128.8(MW)	138(MW)	138(MW)	138(MW)	138(MW)	138(MW)			Turbine maintenance	

Max Farm Production (MW)	Crystal Rig II								Site Capped	Additional Information	Created On
	Expected Max Output (MW)							Estimated End			
	Start	Time 1	Time 2	Time 3	Time 4	Time 5	Time 6				
138	24/08/2016 12:45	24/08/2016 16:45	24/08/2016 20:45	25/08/2016 00:45	25/08/2016 04:45	25/08/2016 08:45	25/08/2016 12:45	24/08/2016 20:45	N		24/08/2016 12:45

Max Farm Production (MW)	Crystal Rig II							Estimated End	Site Capped	Additional Information	Created On
	Expected Max Output (MW)										
	Start	Time 1	Time 2	Time 3	Time 4	Time 5	Time 6				
138	128.8(MW)	128.8(MW)	138(MW)	138(MW)	138(MW)	138(MW)	138(MW)	24/08/2016 20:20	N	all 4 turbines offline for maintenance works	24/08/2016 12:30
	24/08/2016 12:20	24/08/2016 16:20	24/08/2016 20:20	25/08/2016 00:20	25/08/2016 04:20	25/08/2016 08:20	25/08/2016 12:20				
138	0(MW)	0(MW)	0(MW)	0(MW)	0(MW)	0(MW)	138(MW)	19/08/2016 15:00	N	Outage ongoing.	18/08/2016 15:19
	18/08/2016 15:00	18/08/2016 19:00	18/08/2016 23:00	19/08/2016 03:00	19/08/2016 07:00	19/08/2016 11:00	19/08/2016 15:00				
138	0(MW)	138(MW)	138(MW)	138(MW)	138(MW)	138(MW)	138(MW)	18/08/2016 16:00	N	Outage extended.	18/08/2016 12:11
	18/08/2016 12:00	18/08/2016 16:00	18/08/2016 20:00	19/08/2016 00:00	19/08/2016 04:00	19/08/2016 08:00	19/08/2016 12:00				
138	0(MW)	0(MW)	0(MW)	0(MW)	0(MW)	138(MW)	138(MW)	18/08/2016 14:16	N	SCADA works ongoing all turbines to remain off overnight.	17/08/2016 21:21
	17/08/2016 21:16	17/08/2016 22:16	18/08/2016 02:16	18/08/2016 06:16	18/08/2016 10:16	18/08/2016 14:16	18/08/2016 18:16				
138	0(MW)	0(MW)	138(MW)	138(MW)	138(MW)	138(MW)	138(MW)	17/08/2016 18:00	N	Siemens are preparing to disconnect SCADA to CR2 to allow hardware upgrades for future SCADA connection for CR3. During this upgrade all 60 turbines will be remotely shutdown and remain offline for the duration of the works.	17/08/2016 10:05
	17/08/2016 10:00	17/08/2016 14:00	17/08/2016 18:00	17/08/2016 22:00	18/08/2016 02:00	18/08/2016 06:00	18/08/2016 10:00				

Max Farm Production (MW)	Crystal Rig II							Estimated End	Site Capped	Additional Information	Created On
	Expected Max Output (MW)										
	Start	Time 1	Time 2	Time 3	Time 4	Time 5	Time 6				
138	0(MW)	-	-	-	-	-	-	17/08/2016 17:00 Cancelled	N	Siemens are preparing to disconnect SCADA to CR2 to allow hardware upgrades for future SCADA connection of CR3. During this upgrade all 60 turbines will be shutdown remotely and remain off for the duration of the works.	11/08/2016 15:06
	16/08/2016 09:00 Cancelled	-	-	-	-	-	-				