

Max Farm Production (MW)	Fallago Rig								Site Capped	Additional Information	Created On	
	Expected Max Output (MW)							Estimated End				
	Start	Time 1	Time 2	Time 3	Time 4	Time 5	Time 6					
0	0(MW)	-	-	-	-	-	-	-	13/02/2019 16:30	Y	DNO Outage : DNO Outage	08/02/2019 13:53
	11/02/2019 08:30	-	-	-	-	-	-	-				
144	12(MW)	-	-	-	-	-	-	-	13/02/2019 16:30	N	DNO Outage	08/02/2019 13:51
	11/02/2019 08:30	-	-	-	-	-	-	-				
144	0(MW)	-	-	-	-	-	-	-	14/09/2018 14:00	N	Fallago Windfarm outage on SGT1A & SGT1B for maintenance.	22/08/2018 11:21
	10/09/2018 09:00	-	-	-	-	-	-	-				
144	0(MW)	-	-	-	-	-	-	-	14/10/2018 14:00	N	Fallago Windfarm outage on SGT1A & SGT1B for maintenance.	22/08/2018 11:00
	10/09/2018 09:00	-	-	-	-	-	-	-				
144	144(MW)	144(MW)	144(MW)	144(MW)	144(MW)	144(MW)	144(MW)	-	30/05/2018 17:00	N	The current outage that affected Fallago Rig is now completed and the site has been re-energised and is now in production	30/05/2018 13:25
	30/05/2018 13:00	30/05/2018 17:00	30/05/2018 21:00	31/05/2018 01:00	31/05/2018 05:00	31/05/2018 09:00	31/05/2018 13:00	-				
144	0(MW)	-	-	-	-	-	-	-	30/05/2018 16:30	N	Fallago Rig Windfarm is completely offline to accommodate an DNO Outage.	29/05/2018 11:42
	29/05/2018 11:00	-	-	-	-	-	-	-				
100	0(MW)	100(MW)	100(MW)	100(MW)	100(MW)	100(MW)	100(MW)	-	22/03/2018 20:00	Y	Loss of Transformer SGT1B : Work for Restoration of SGT1B	20/03/2018 13:29
	22/03/2018 16:00	22/03/2018 20:00	23/03/2018 00:00	23/03/2018 04:00	23/03/2018 08:00	23/03/2018 12:00	23/03/2018 16:00	-				
100	100(MW)	-	-	-	-	-	-	-	05/03/2018 00:00	Y	Single SGT operation : Single SGT operation	26/02/2018 15:56
	26/02/2018 15:54	-	-	-	-	-	-	-				
144	0(MW)	0(MW)	144(MW)	144(MW)	144(MW)	144(MW)	144(MW)	-	13/01/2017 16:30	N	HV Isolations on SGT1B to allow for Surge Arrestor replacement : All WTG'S offline to facilitate outage	12/01/2017 14:48
	13/01/2017 08:30	13/01/2017 12:30	13/01/2017 16:30	13/01/2017 20:30	14/01/2017 00:30	14/01/2017 04:30	14/01/2017 08:30	-				
0	0(MW)	0(MW)	0(MW)	0(MW)	0(MW)	0(MW)	0(MW)	-	13/01/2017 16:30	Y	HV Isolations on SGT1B to allow for Surge Arrestor replacement : All WTG'S offline to facilitate outage	12/01/2017 14:12
	13/01/2017 08:30	13/01/2017 12:30	13/01/2017 16:30	13/01/2017 20:30	14/01/2017 00:30	14/01/2017 04:30	14/01/2017 08:30	-				
72	72(MW)	-	-	-	-	-	-	-	17/08/2016 12:00	Y	33kV Switchboard Maintenance. : 24 turbines offline for 33kV Switchboard Maintenance.	15/08/2016 09:59
	15/08/2016 09:00	-	-	-	-	-	-	-				
0	0(MW)	-	-	-	-	-	-	-	12/08/2016 15:00	Y	Reason for Site Cap. SPT performing Grid maintenance. : HV network Off.	05/08/2016 15:58
	08/08/2016 12:00	-	-	-	-	-	-	-				