

Max Farm Production (MW)	Beinneun Wind Farm								Site Capped	Additional Information	Created On	
	Expected Max Output (MW)							Estimated End				
	Start	Time 1	Time 2	Time 3	Time 4	Time 5	Time 6					
95	95(MW)	-	-	-	-	-	-	-	15/08/2021 17:00	Y	Capacity Share to allow Transmission Works. From 1400 on 18/6/2021 Natural Power will no longer have responsibility for REMIT declarations for this unit	18/06/2021 12:46
	18/06/2021 12:30	-	-	-	-	-	-	-				
108.8	0(MW)	0(MW)	108.8(MW)	108.8(MW)	108.8(MW)	108.8(MW)	108.8(MW)	108.8(MW)	14/04/2021 17:00	N	Planned outage TOGA MG125597	14/04/2021 09:06
	14/04/2021 09:00	14/04/2021 13:00	14/04/2021 17:00	14/04/2021 21:00	15/04/2021 01:00	15/04/2021 05:00	15/04/2021 09:00					
33.5	33.5(MW)	33.5(MW)	33.5(MW)	33.5(MW)	33.5(MW)	33.5(MW)	33.5(MW)	33.5(MW)	04/09/2020 16:00	Y	Constrained to 33.5MW (SSE Deloading GT1 at Fort Augustus : .	31/08/2020 22:00
	04/09/2020 08:00	04/09/2020 12:00	04/09/2020 16:00	04/09/2020 20:00	05/09/2020 00:00	05/09/2020 04:00	05/09/2020 08:00					
33.5	33.5(MW)	-	-	-	-	-	-	-	31/08/2020 16:00	Y	Fault on the 132kV at Fort Augustus : none	31/08/2020 17:42
	31/08/2020 09:00	-	-	-	-	-	-	-				